

**PRELIMINARY ENGINEERING REPORT**  
**for the**  
**WASTEWATER TREATMENT SYSTEM**  
**In**  
**LAKE FOREST ESTATES**  
**SAINTE GENEVIEVE COUNTY, MISSOURI**



Prepared By  
Richard E. Cochran, Jr., P.E.

**Waters Engineering, Inc.**

Civil Engineering & Land Surveying  
Sikeston, Missouri  
573-471-5680



January 2, 2020

## **TABLE OF CONTENTS**

1. GENERAL INFORMATION
2. PLANNING AREA
3. ECONOMIC AND DEMOGRAPHIC DATA
  - 3.1 Land Use
  - 3.2 Population
4. ENVIRONMENTAL DATA
  - 4.1 Topography
  - 4.2 Soils
5. EXISTING SYSTEMS
  - 5.1 Water System
  - 5.2 Wastewater System
    - 5.2.1 Wastewater Collection System
    - 5.2.2 Wastewater Treatment System
    - 5.2.3 Wastewater Flow and Effluent Quality
6. DESIGN PARAMETERS
  - 6.1 Wastewater Treatment
7. EXISTING SYSTEM DEFICIENCIES
  - 7.1 Existing Wastewater Collection System
  - 7.2 Existing Wastewater Treatment Facilities
8. ALTERNATE SOLUTIONS
  - 8.1 Sewer Collection System
    - 8.1.1 Do Nothing
    - 8.1.2 Line the Gravity Mains with CIPP
    - 8.1.3 Replace Portions of the Gravity Mains with a Pressure System
    - 8.1.4 Replace Portions of the Gravity Mains with New Gravity Piping
  - 8.2 Wastewater Treatment Facility
    - 8.2.1 Do Nothing

- 8.2.2 Modify the Existing Treatment Plant to a No-Discharge System
- 8.2.3 Move the Discharge or Treatment Plant to a Different Receiving Stream

- 8.2.3.1 Modification of the Existing Aerated Lagoon

- 8.2.3.1.1 Conversion to Activated Sludge
  - 8.2.3.1.2 Conversion to Lagoon with Fixed Film Media

- 8.2.3.2 Construction of a New Treatment Plant

- 8.2.3.2.1 Activated Sludge Treatment Plant

- 8.2.3.3 Relocated Discharge Treatment Plant Comparisons

- 8.2.4 Maintain the Existing Discharge Location

- 8.2.4.1 Modification of the Existing Aerated Lagoon by Conversion to an Activated Sludge System
  - 8.2.4.2 Construction of a New Treatment Plant
  - 8.2.4.3 Existing Discharge Location Comparisons

- 8.3 Alternative Comparison

- 8.3.1 Wastewater Collection
  - 8.3.2 Wastewater Treatment

- 8.4 Alternative Recommendation

- 9. OPTIONS FOR FINANCING

- 9.1 Community Development Block Grant Program
  - 9.2 State Rural Sewer Grant
  - 9.3 State Revolving Fund
  - 9.4 USDA Rural Development Grant/Loan
  - 9.5 Revenue or General Obligation Bonds
  - 9.6 Lease Financing

- 10. RECOMMENDATIONS FOR FINANCING

- 11. LOCAL COSTS

- 11.1 No Grant Funds Involved
  - 11.2 Grant Funds Involved

- 12. RECOMMENDATIONS

## **LIST OF FIGURES**

Figure 1, Vicinity Map  
Figure 2, Topographic Map  
Figure 3, Existing Lagoon Layout  
Figure 4, Proposed Collection System Improvements  
Figure 5, Proposed SBR Lagoon Layout

## **LIST OF EXHIBITS**

Exhibit 1, MDNR Operating Permit  
Exhibit 2, Grant Eligibility Form

## 1. GENERAL INFORMATION

This study was instituted in order to evaluate the existing wastewater system, determine its needs, evaluate its adequacy for growth, and provide recommendations to help the system meet its future needs.

This report is an engineering study to determine the proper course of action to develop a wastewater system that will be adequate to serve the Subdivision for the next 20 years. It has been prepared from data obtained through field surveys, information provided by the Subdivision, and studies relative to the design of a complete wastewater system.

The study indicates that improvements are needed to meet future DNR requirements. In order to finance these improvements, loans may be necessary.

## 2. PLANNING AREA

Lake Forest Estates is located in Sainte Genevieve County as shown in Figure 1, *Vicinity Map*. It is located in the northwest part of the county approximately 10 miles west of Sainte Genevieve and 6 miles southwest of Bloomsdale. The planning area will include the complete subdivision as can be seen on Figure 2, *Topographic Map*.

Planned but undeveloped lots should be considered in the system design; but, the expenses to construct additional collection system lines, connections, or roads will not be shown in these cost estimates. It will be assumed that these costs will be borne by the future homeowners.

The planning period for this study is for 20 years, which means that all designs will be for the anticipated conditions that will exist in the year 2040.

The property owners of Lake Forest Estates Community Association recently formed the Lake Forest Clean Water District who is responsible for the planning, financing, and operating of the water and wastewater system. They have a licensed water and wastewater operator and have the authority to set and increase user rates to finance improvements to the systems.

## 3. ECONOMIC AND DEMOGRAPHIC DATA

Lake Forest Estates is a residential area. There are no industrial, commercial, institutional, or educational entities within the planning area.

### 3.1 Land Use

The present limits of Lake Forest Estates contains over 640 acres. There are approximately 286 residences in the Subdivision and additional room available for 60 more residences.

### 3.2 Population

Based upon a 1999 census taken in the subdivision, the average household has 2.7 occupants, therefore, the current population in the Subdivision is 773 people. The 2000 census for Sainte

Genevieve County also shows an average household of 2.7 people which coincides with the survey.

With additional space available for only 60 more homes, the Subdivision can see a maximum growth of 11% or 346 homes.

Therefore, a total planning area design population equivalent of 935 will be used.

Since the Subdivision is not a community, there is no census data for the local income. The subdivision is located within Ste. Genevieve Township in Ste. Genevieve County however, and there is census data for the township. From American Factfinder, the 2010 median household income for the township is \$44,509.

#### 4. ENVIRONMENTAL DATA

##### 4.1 Topography

The topography of Lake Forest Estates is hilly, as evidenced by the contour lines on Figure 2, *Topographic Map*. Elevations range from 480 feet mean sea level (MSL) to 660 feet MSL.

Lake Forest Estates lies in the hills around three manmade lakes with the largest being approximately 81 acres. The only entrance to the Subdivision (Lakewood Drive) is located off of State Route "O".

##### 4.2 Soils

The predominate soil of the area is of the Union-Goss-Gasconade-Crider Complex. It is characterized by steep and very steep soils on upland side slopes. It includes small areas of pasture and cultivated land on gently to moderately sloping ridgetops, and forested, long, moderate to very steep side slopes. The soils have formed in cherty limestone residual material, although Union and Crider soils also have a thin mantle of loess present.

Union soils are characterized by having a hardpan layer; however, they are moderately well drained. They have a silt-loam topsoil grading downward into a moderately permeable subsoil overlying a massive hardpan.

Goss soils are deep, well drained, and occur on steep upland slopes of from 2% to 45%. They have a cherty, silt-loam topsoil overlying a moderately permeable, very cherty, silty-clay subsoil.

Gasconade soils are shallow, somewhat excessively drained, and occur on steep upland slopes. They have a flaggy clay-loam topsoil overlying a flaggy, clay subsoil that has moderately slow permeability. These soils occur on slopes ranging from 2% to 50%.

Crider soils are deep, well drained upland soils that also occur in some area with karst topography. They have a silt loam topsoil overlying a moderately permeable, silty-clay-loam subsoil. The slopes on which they occur range from nearly flat to 20%.

With the exception of the Crider soils, all of these have a low to very low available water capacity.

## 5. EXISTING SYSTEMS

### 5.1 Water System

Water is supplied to the residents through a State licensed non-transient community water supply system.

The water supply is composed of two deep consolidated wells. From the well, the water is disinfected and pumped to a ground storage standpipe located near one of the wells. From the standpipe, the water pressurizes the distribution system under gravity which supplies all of the homes and buildings in the subdivision.

### 5.2 Wastewater System

#### 5.2.1 Wastewater Collection System

Wastewater in and around Lake Forest Estates is transported beneath the lakes to a wastewater treatment lagoon north of the dam through 6-inch and 8-inch diameter pvc truss wall pipes and cast-in-place manholes. No manholes are located beneath the water level of the lake. They are located in the laterals surrounding the lake. The Subdivision has had problems with infiltration/inflow (I&I). They are continuously smoke testing and inspecting manholes to find sources. From this data they have repaired many leaks and raised the height of several manholes.

The collection system was installed in 1971 beneath the lake and is therefore prone to excessive infiltration when a leak develops. In 2001 when improvements to upgrade the treatment system were made, site visits did not show an excessive flow of water which would be typical with infiltration; but, flow metering was performed and daily flows measured. It was shown at that time, inflow existed during wet weather events. These flows met levels of 640,000 gpd. Since that time, the Association installed a flow meter on the treatment plant effluent to help them detect and measure excessive flows. Using that data, they have made many improvements in an effort to reduce I/I. They still have excessive I/I. In the past two years, the peak measured flow has been 556,000 gpd.

#### 5.2.2 Wastewater Treatment System

From the collection system, the sewage currently flows by gravity into a three cell aerated lagoon. It was designed for a dry weather flow of 118,300 gallons per day; but, because of the infiltration during storm events, it was also sized to handle a wet weather flow of 376,700 gallons per day and the previous facultative lagoon is being utilized for equalization for excessive daily peak wet weather flows. The old lagoon system was deemed capable of handling 5 consecutive days worth of peak flows. Figure 3, Existing Lagoon Layout shows the current facility layout.

This facility discharges to Big Bottom Creek which is on MDNR's 303d list as an impaired waterway. The EPA developed a Total Maximum Daily Load (TMDL) in 2010 which was published and approved. This TMDL set Waste Load Allocations (WLA's) which produces effluent limits that are unattainable by any known treatment methods. Missouri DNR has recently revised this TMDL and has it on public notice. The existing permit; however, has limits based upon the WLA's from the 2010 TMDL. These limits were proposed in a phased manner.

This most recent permit (issued on February 1, 2016), implemented effluent limits that the current treatment plant could not meet. Because the Association has been working to pay off the debt on the lagoon improvements of 2005, they were not in a financial condition to make additional improvements. They have been attempting to negotiate with DNR for some relief. This permit is shown as Exhibit 1, MDNR Operating Permit at the end of this report. This permit imposed the following monthly limits on their system:

<u>Parameter</u>	<u>Volumetric</u>
BOD	30 mg/L
TSS	30 mg/L
NH3 (summer)	1.9 mg/L
NH3 (winter)	3.7 mg/L

In the year 2022, this permit will change the limits to:

<u>Parameter</u>	<u>Volumetric</u>
BOD	10 mg/L
TSS	10 mg/L
NH3 (summer)	0.6 mg/L
NH3 (winter)	2.1 mg/L
eColi	206 #/100mL

In the year 2029, this permit will again change the limits to:

<u>Parameter</u>	<u>Volumetric</u>	<u>Mass Loading</u>
CBOD	5.04 mg/L	4.99 lbs/day
NBOD	1.46 mg/L	1.45 lbs/day
TSS	10 mg/L	9.9 lbs/day
NH3 (year round)	0.3 mg/L	0.8 lbs/day
eColi	206 #/100mL	
Total Nitrogen	0.289 mg/L	0.29 lbs/day
Total Phosphorus	0.007 mg/L	0.01 lbs/day
Dissolved Oxygen	8.0 mg/L	

The District has met with DNR multiple times to obtain relief from the 2019 limits as they are unattainable. To date, the best that has been offered was the recommendation to make improvements for the 2022 limits after which time DNR will perform a lifeform survey to see if the impairments to the stream have gone away and new lifeforms are developing. If that is the case, then DNR can revise the permit to not include the 2029 limits.



If not, then, the District would have to make improvements to meet the 2029 limits or request a variance based upon the financial hardships of making additional improvements as well as noting the attainability of those limits.

Since then a new TMDL prepared by Missouri DNR has been put on public notice. If this TMDL is implemented, it could relax some of the 2029 limits; but, tighten others. The effluent limits that would be expected from this TMDL are as follows:

<u>Parameter</u>	<u>Volumetric</u>
BOD	5 mg/L
TSS	10 mg/L
NH3 (yearly)	1 mg/L
Total Nitrogen	5 mg/L
Total Phosphorus	0.5 mg/L
eColi	206 #/100mL
Dissolved Oxygen	6 mg/L

### 5.2.3 Wastewater Flow and Effluent Quality

The records from 2017 through now show the following sample results:

<u>Date</u>	<u>BOD</u>	<u>TSS</u>	<u>NH3 (S)</u>	<u>NH3 (W)</u>	<u>TN</u>	<u>TP</u>	<u>Q (avg)</u>	<u>Q (peak)</u>	<u>D.O.</u>
17-Jan	14.3	10		8.14			0.1092	0.257	6.6
17-Feb	6.49	16		9.09			0.07	0.081	7.6
17-Mar	28.8	22		6.05	18.44	1.14	0.098	0.239	10.5
17-Apr	16.2	34	11.4				0.177	0.671	9.2
17-May	18.2	13	0.05				0.07	0.414	7.8
17-Jun	12.1	17	0.05		26.9	1.63	0.07	0.27	5.2
17-Jul	5.07	9	0.05				0.091	0.14	5
17-Aug	11.8	8	0.05				0.086	0.205	
17-Sep	14.9	7	0.053		5.41	0.79	0.065	0.111	
17-Oct	9.65	20		0.05			0.063	0.102	
17-Nov	7	19		0.05			0.074	0.102	
17-Dec	18	30		0.05	7.25	0.91	0.09	0.142	
18-Jan	13.1	8		5.75			0.08	0.139	
18-Feb	11.8	9		7.43			0.128	0.421	12.6
18-Mar	13.4	8		5.68	12.7	1.3	0.163	0.272	12.2
18-Apr	15.9	29	0.552				0.136	0.19	6.3
18-May	14.4	14.4	0.02				0.111	0.196	6.3
18-Jun	14.8	10.5	1.1		7.15	2.98	0.116	0.255	
18-Jul	21.5	13	9.08				0.087	0.149	
18-Aug	40.6	16	4.45				0.01	0.164	
18-Sep	15.2	14	0.02		14.5	4.25	0.112	0.556	4.4
18-Oct	16.8	9		1.56			0.086	0.12	6.8
18-Nov	20.3	11		0.242			0.129	0.267	12.6
18-Dec	12.8	7		6	17.3	2.07	0.147	0.432	
19-Jan	14.1	4		6.8			0.16	0.241	12.2
19-Feb	8.89	6		5.34			0.227	0.355	15.9
19-Mar	10.8/	12		3.51	10.1	1.29	0.175	0.328	11.4
19-Apr	17	9	4.43				0.172	0.258	9
19-May	5.42	6	6.76				0.17	0.379	8.2
19-Jun	5.35	7	9.29		6.31	3.4	0.11	0.217	5.8
19-Jul	14.3	8	8.45				0.099	0.275	
19-Aug	59.7	8	8.41				0.079	0.13	
19-Oct	13.3	10		6.01	7.91	1.9	0.095	0.188	

As you can see from the data, the system is doing fine at meeting the current requirements for BOD and TSS; however, it does not meet the Ammonia (NH3) limits. The system has been in violation of its permit in 15 months of the past 2 years.

In addition, once the phase II limits are implemented in 2022, the Plant will not consistently meet any of the discharge limits.

This data also shows that the average daily flow to the lagoon for the past three years has been 111,256 gpd. Using dry summer months of June through October, the average daily flow during that same time frame is 89,200 gpd. From water pumping records at the wells, the water supply has been producing only 60,360 gpm during that same time period. This is indicative of infiltration in the wastewater collection system.

## 6. DESIGN PARAMETERS

### 6.1 Wastewater Treatment

With 286 existing homes, the current population equivalent is 773 persons. The lagoon loadings will be based upon the DNR recommendation of 0.17 lb/person/day and infiltration/inflow strengths of 30 mg/L. The flows will be based upon the existing water production rates of 78 gpcd.

For the design capacity, the future population will be used. This population is based upon the subdivision capacity of 346 homes and is estimated at 935.

It is known that the I/I will not be eliminated. Improvements can be made; but, as shown by the Associations past work, the repairs only last a few years before the flows begin climbing again. With that thought in mind, the future infiltration will remain as existing and the future inflow will be reduced by 25%. The existing flows and future design capacity is being presented below:

#### Flows (gpd)

<u>Condition</u>	<u>Population</u>	<u>Water Use</u>	<u>Infiltration</u>	<u>Inflow</u>	<u>Total</u>
<i>Existing</i>					
Average Flow	773	60,400	28,900	22,000	111,300
Peak Flow	773	60,400	28,900	466,700	556,000
<i>Future</i>					
Average Flow	935	73,100	28,900	16,500	118,500
Peak Flow	935	73,100	28,900	350,100	452,100

#### Loadings

<u>Condition</u>	<u>Population</u>	<u>Domestic</u>	<u>Infiltration</u>	<u>Inflow</u>	<u>Total</u>
<i>Existing</i>					
Average Flow	773	132	8	6	132
Peak Flow	773	132	8	117	243
<i>Future</i>					
Average Flow	935	159	8	5	172
Peak Flow	935	159	8	88	255

## 7. EXISTING SYSTEM DEFICIENCIES

### 7.1 Existing Wastewater Collection System

From the previous sections it is evident that there is extra water entering the collection system from outside the residential connections. This indicates that the collection system leaks.

From visual inspections, the majority of the sewer collection system is constructed of truss pipe. This pipe is known to become brittle and develop leaks.

From the average daily flows, it appears that there is approximately 50,900 gallons per day in excess of their water system production. This does not even account for any potential water system losses through leaking pipes. It is estimated that this flow is coming from leaks in the sewer lines below the lakes.

The peak daily flows from the past 2.5 years of data show that the peak day includes an additional 445,000 gallons of water during a wet weather event. It is estimated that this flow is coming from leaking sewer lines along the edge of the lakes and under the streams feeding the lakes.

The District does smoke test their system at times and does visual flow monitoring to locate sources of I/I. When this occurs, they find and repair broken mains. They also lower the lake levels during select winters and perform main repairs along the edges of the lakes on a regular basis.

With this occurring on regular basis, the District knows the system is faulty and has not been able to solve the problem. They can only seem to manage the I/I and keep it reduced to a medium/high level.

### 7.2 Existing Wastewater Treatment Facilities

A visual inspection of the lagoon showed no obvious defects. The District is doing an excellent job of maintaining the facilities. The existing equalization lagoons are being mowed when dry which keeps pests and vermin from breeding and causing damage to cell levees.

It is apparent from the testing results that the lagoon is not capable of meeting newer effluent limits. Regulations were changing in 2001 when the current lagoon was being designed. No one knew what the future regulations would be at that time and DNR presented effluent limits which could change. It was estimated that Ammonia limits would be enforced; however, no one knew to what extent (how low the limits would be). The lagoon was designed with a deeper water depth and smaller surface area to help reduce future upgrade costs.

The time has come for the District to begin looking at those upgrades. Some ammonia limits are already under enforcement and not being met. Lower limits of all parameters will have to be met in a few years and even lower unattainable limits may need to be dealt with in the future.

Meetings with DNR resulted in verbal authorization to make improvements designed to meet the 6 year limits. Then, after construction and operation for a few years, DNR could re-evaluate

the stream and if it re-attains it's intended uses, could request a permit modification eliminating the 13 year limits unless the new TMDL is approved and other limits are implemented. There is no guarantee; however, that the stream would re-attain it's uses or that the state officials at that time will allow the permit to be modified.

## 8. ALTERNATE SOLUTIONS

### 8.1 Sewer Collection System

Because the Clean Water District will be taking over the water and sewer, they will not be able to charge an annual maintenance fee like the Home Owners Association. Therefore, metering should be installed on the water service lines to provide a fair method of allocating costs. This should be done regardless of the collection or treatment system recommended.

#### 8.1.1 Do Nothing

Doing nothing is really not an alternative. Doing nothing will allow the I/I to increase and become unmanageable. At some point it will overwhelm the treatment plant and the shallow sloping gravity mains below the dam. There it will overflow the manholes and run into the receiving stream without treatment. The high flows that go to the plant will not receive adequate treatment and can also wash sludge from the treatment plant.

#### 8.1.2 Line the Gravity Mains with CIPP

Lining some of the mains is an option; however, only those lines which are above the water level.

CIPP linings are limited to 500 or 600 feet in length and for the installation, it is required that both ends of the pipe to be lined are exposed for access. The lines beneath the lakes are thousands of feet long. Over 25,000 feet of gravity sewer main lies beneath the water surface which can be over 40 feet deep at the dam. It is not possible to expose deeper sections of the line without draining the entire lake and the community is not agreeable to that.

There are also multiple wyes on the main under the lake and getting access for all of those is difficult as explained above.

#### 8.1.3 Replace Portions of the Gravity Mains with a Pressure System.

It is possible to install grinder pumps at the manhole locations adjacent to the lake shoreline. These grinder stations would serve one or more residences and then pump the waste around the shoreline to the treatment plant.

These stations would be connected to forcemains ranging from 2-inch diameter up to 4-inch diameter. The forcemain would run along the edge of the roadway and discharge at the treatment plant below the dam.

Most of the stations serve multiple homes so duplex stations would be utilized to provide a backup pump if one were clogged or failed. Because the pumps house grinder blades to chop

any solids into smaller particles that can pass through, a 2 HP motor is recommended. This larger motor would run cooler, clog less, and provide a longer lifespan.

Portions of the system not beneath the lake would be retained as gravity flowing to the grinder stations. These lines would be inspected via smoke testing and CCTV video and repairs made based upon these inspections.

The advantages of a pressure system are:

- a. All of the collection lines will be located outside of the lakes and accessible for repair.
- b. Leaks from pressure lines typically surface and are more easily found.

Disadvantages include:

- a. Higher maintenance with grinder pumps.
- b. Requires more operator attention to check pumps.
- c. More expensive to operate due to the use of pumps.
- d. Additional easements will be needed from the homeowners.

The estimated construction cost for the pressure sewer system upgrade is shown below:

*Pressurized Collection System*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	Duplex Grinder Lift Stations	76	EA	\$ 18,000.00	\$ 1,368,000.00
2	Forcemain	37600	LF	\$ 18.00	\$ 676,800.00
3	Electrical Supply	76	EA	\$ 1,000.00	\$ 76,000.00
4	Gravity Connections	91	EA	\$ 1,000.00	\$ 91,000.00
5	Sitework	76	EA	\$ 600.00	\$ 45,600.00
Subtotal Metering Cost					\$ 2,257,400.00

*Sewer Repair*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	Manhole Liners	235	EA	\$ 900.00	\$ 211,500.00
2	CIPP Gravity Repair	3250	LF	\$ 50.00	\$ 162,500.00
Subtotal Collection System Cost					\$ 374,000.00

*Metering*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	5/8"x3/4" Meter, Base, Box	300	EA	\$ 900.00	\$ 270,000.00
2	Computer, Software & Support	1	EA	\$ 20,000.00	\$ 20,000.00
Subtotal Metering Cost					\$ 290,000.00

Total Construction Cost	\$ 2,921,400.00
Collection System Inspection	\$ 79,259.10
Engineering Design	\$ 228,900.00
Construction Observation	\$ 171,700.00
Legal	\$ 15,000.00
Closing Costs	\$ 15,000.00
Environmental	\$ 7,500.00
Contingencies	\$ 292,000.00
<b>TOTAL PROJECT COST</b>	<b>\$ 3,730,759.10</b>

In addition there are other cost factors to look at and those are the operation and maintenance of the facilities. The District already has a full time operator for the water and wastewater so labor will not be included in the evaluation. Power and repairs will be necessary however.

Below is a chart outlining some of the added operation and maintenance items with their estimated costs:

Annual Treatment System O&M			
<u>System Type</u>	<u>Power</u>	<u>Repl.</u>	<u>Total</u>
Pressure Sewer	\$13,700	\$37,100	\$50,800

#### 8.1.4 Replace Portions of the Gravity Main with New Gravity Piping.

Another option would be to replace portions of the gravity main in shallow waters with new ductile iron pipe. This option would replace the existing lines that are subject to damage from anchors and expansion/contraction due to temperature changes. The deeper lines are less prone to problems from these as they are in more temperate water conditions.

New lines under Lake Anne would be run from the manholes on the shorelines into the water and then parallel along the banks close to the shoreline. On the smaller shallower lakes, they would be replaced adjacent to the existing lines. The smaller lakes would have to essentially be drained and the Lake Anne drained to a lower level. The Association is not in agreement with draining Lake Anne dry but, draining to a lower level is acceptable.

As much of these shallower waters have developed siltation over the years, it will be necessary to remove some of this to allow the new lines to be placed below the actual lake bottom.

As above, the portions of the system not beneath the lake would be inspected and repairs made based upon the inspections.

The advantages of the gravity system are:

- a. Lower maintenance costs.
- b. Lower operating costs since power is not required.
- c. Less operator attention is required.

Disadvantages include:

- a. Leaking lines beneath the lake more difficult to locate and repair.
- b. Still possibility of leaking lines beneath the water surface.



The estimated construction cost for the gravity sewer system upgrade is shown below:

*Lake Anne*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	Excavation & Removal	12600	CY	\$ 25.00	\$ 315,000.00
2	8" DIP Gravity Sewer	7050	LF	\$ 100.00	\$ 705,000.00
3	Manholes	21	EA	\$ 5,000.00	\$ 105,000.00
4	Tie-ins	19	EA	\$ 3,000.00	\$ 57,000.00
5	Line Plugs	4	EA	\$ 5,000.00	\$ 20,000.00
Subtotal Collection System Cost					\$ 1,202,000.00

*Lake Marian*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	8" DIP Gravity Sewer	5178	LF	\$ 100.00	\$ 517,800.00
2	Manholes	16	EA	\$ 5,000.00	\$ 80,000.00
3	Tie-ins	12	EA	\$ 3,000.00	\$ 36,000.00
Subtotal Collection System Cost					\$ 633,800.00

*Lake Susan*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	8" DIP Gravity Sewer	2088	LF	\$ 100.00	\$ 208,800.00
2	Manholes	9	EA	\$ 5,000.00	\$ 45,000.00
3	Tie-ins	9	EA	\$ 3,000.00	\$ 27,000.00
Subtotal Collection System Cost					\$ 280,800.00

*Sewer Repair*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	Manhole Liners	243	EA	\$ 900.00	\$ 218,700.00
2	CIPP Gravity Repair	3310	LF	\$ 50.00	\$ 165,500.00
Subtotal Collection System Cost					\$ 384,200.00

*Metering*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	5/8"x3/4" Meter, Base, Box	300	EA	\$ 900.00	\$ 270,000.00
2	Computer, Software & Support	1	EA	\$ 20,000.00	\$ 20,000.00
Subtotal Metering Cost					\$ 290,000.00

Total Construction Cost	\$ 2,790,800.00
Collection System Inspection	\$ 81,365.00
Engineering Design	\$ 220,100.00
Construction Observation	\$ 165,100.00
Legal	\$ 15,000.00
Closing Costs	\$ 15,000.00
Environmental	\$ 7,500.00
Contingencies	\$ 279,000.00
TOTAL PROJECT COST	\$ 3,573,865.00

Like the pressure sewer, there are some additional cost factors to look at but with gravity sewer, they are fewer. Because power is not required, the only maintenance will be associated with the water meters.

Below is a chart outlining some of the added operation and maintenance items with their estimated costs:

<u>System Type</u>	Annual Treatment System O&M		
	<u>Power</u>	<u>Repl.</u>	<u>Total</u>
Gravity Sewer	\$0	\$ 6,700	\$ 6,700

## 8.2 Wastewater Treatment Facility

Meeting ammonia limits is not the only issue with this system. The future limits being implemented are more stringent and impossible to meet. Not only does the District have to look at what upgrades are necessary, they also have to determine a course of action before the upgrades can be decided. There are several courses that the District could take. These include the following:

### 8.2.1 Do Nothing

Doing nothing is one alternative. The existing wastewater discharge permit includes limits which are not being met. If these limits are not met DNR will begin to enforce the state regulations through the court system. This would result in the District taking a legal pathway. The ultimate discharge requirements would then be determined by the courts.

### 8.2.2 Modify the Existing Treatment Plant to a No-Discharge System.

A no-discharge system would eliminate the discharge permit and thereby eliminate the limits imposed by such permit. This option should carry the District through many decades without requiring upgrades for a change in limits. The largest hurdle for this type of system is the acquisition of land. There is not enough available land within the subdivision so ground would have to be purchased or rented on which to distribute the water.

The main type of no-discharge system at a facility of this size is land application. Primary treatment is needed in the form of a lagoon and the effluent is pumped to irrigation nozzles that spray the wastewater on surrounding ground.

The primary treatment lagoons must have a minimum of 90 days of wastewater storage with an allowance of 2 feet for sludge and an allowance for the precipitation that occurs during this period to allow for cold and wet weather conditions that will not allow land application. The typical annual precipitation is 42 inches; with a 1 in 10 year rainfall minus evaporation total of 12 inches over 90 days. With a high water depth of 10.5 feet, the area of the lagoon should be approximately 4.11 acres. This will require additional earthwork at the existing lagoon site.

The land application rate would be designed for 36 inches per acre per year, 3 inches per acre per week, or 1 inch per acre per day. With an annual flow of 43,200,000 gallons and a storm volume of approximately 4,000,000 gallons, there are 47,200,000 gallons to land apply. With a maximum annual application of 36 inches, the land application area will encompass 48 acres. If

a 12 hour/day application period is used with an application rate of 1/2 inch/acre per day, the effluent pump will be sized for 1,471 gpm. This will require 48 days of application per year.

A land application pumping station, control panel, discharge piping, control valves, application area (land), and irrigation nozzles (big guns) will be needed in addition to the lagoon improvements.

Operation of a land application system will require the operator to visit the site on a daily basis and pump wastewater to the application area as weather permits.

Several years ago, the Association previously contacted nearby land owners to find out if land could be purchased, leased, or used for this purpose and they met with resistance. Since they are now a District, they may have more legal options available for land acquisition or there may be new land owners that are agreeable.

The advantages of a land application system are:

- a. It is a non-discharge system that doesn't require stringent testing.
- b. Doesn't harm aquatic life if operated properly.
- c. It is relatively easy to operate.

Disadvantages include:

- a. Higher maintenance as system ages.
- b. Requires closer attention as I/I levels increase.
- c. Requires extremely large area of land for application of wastes if available.

The estimated construction cost for the land application system is shown below:

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	Lagoon Earthwork	41000	CY	\$ 25.00	\$ 1,025,000.00
2	Structures	2	EA	\$ 15,000.00	\$ 30,000.00
3	Lift Station	2	EA	\$ 125,000.00	\$ 250,000.00
4	Forcemain	450	LF	\$ 50.00	\$ 22,500.00
5	Controls	1	LS	\$ 50,000.00	\$ 50,000.00
6	Electrical	1	LS	\$ 120,000.00	\$ 120,000.00
7	Sitework	2	AC	\$ 5,000.00	\$ 10,000.00
8	Riprap	1200	Ton	\$ 35.00	\$ 42,000.00
9	Strainer	1	EA	\$ 60,000.00	\$ 60,000.00
10	Gravel Roadway	450	Ton	\$ 35.00	\$ 15,750.00
11	Irrigation Guns	17	EA	\$ 6,000.00	\$ 102,000.00
12	Field Piping	10200	LF	\$ 35.00	\$ 357,000.00
Total Construction Cost					\$ 2,084,250.00
Engineering Design					\$ 171,000.00
Construction Observation					\$ 128,300.00
Interest					\$ 165,000.00
Legal/Bonding					\$ 20,000.00
Environmental					\$ 7,500.00
Land Costs					\$ 1,200,000.00
Contingencies					\$ 208,000.00
TOTAL PROJECT COST					\$ 3,984,050.00

In addition there are other cost factors to look at and those are the operation and maintenance of the facilities. The District already has a full time operator for the water and wastewater so labor will not be included in the evaluation. Power, sludge disposal, and repairs will be necessary however.

Below is a chart outlining some of the added operation and maintenance items with their estimated costs:

<u>System Type</u>	<u>Annual Treatment System O&amp;M</u>			
	<u>Power</u>	<u>Repl.</u>	<u>Sludge</u>	<u>Total</u>
Land Application	\$3,000	\$6,000	\$5,000	\$14,000

### 8.2.3 Move the Discharge or Treatment Plant to a Different Receiving Stream

Another course of action would include relocating the treatment plant or discharge to a different stream such as Indian Creek which isn't on the Departments 303d list and/or doesn't have a TMDL. This could make the effluent requirements less stringent.

An Anti-Degradation Review would have to be completed before the actual limits would be known; but, it could be estimated that the limits would be similar to those seen in other areas of the state. Like land application above, this option requires the availability of land on which to

place the discharge piping and/or treatment plant. The land could be purchased or a lease could be purchased; but, the land would have to be obtained in some fashion.

Regardless of the treatment option, both relocating the effluent of the existing plant or relocating the plant will require gravity flow piping to the new discharge site. The benefit of relocating the discharge of the existing plant would be ease of access, less potential for raw sewage overflow, less land purchase required, and lower costs for reuse of the existing infrastructure (even if only for the equalization basins). It would be better to relocate the discharge.

There are several treatment options available to meet those type of limits and they will be outlined below.

#### 8.2.3.1 Modification of the Existing Aerated Lagoon

Modifications are being completed in other areas of the state in a few different ways. The various options for reuse of the lagoon will be outlined below:

##### 8.2.3.1.1 Conversion to Activated Sludge System

There has been success in utilizing activated sludge lagoon systems, especially in the agricultural industry.

This could be accomplished in a couple ways. All methods would include additional aeration to convert the basins to complete mix activated sludge; but, various options exist for clarifying the water. We feel the most cost effective and operational friendly manner would be to convert the existing lagoon into a Sequencing Batch Reactor.

This upgrade would require splitting the final settling pond into two basins. A concrete wall and liner would split the basin and prevent erosion and leakage. A flow splitter would be constructed at the head of both basins to split the flow evenly between the two. Screening facilities would be incorporated before this splitter to remove any large non-degradable objects that could foul the mechanical equipment. Floating aerator/mixers would be installed on both basins to aerate and mix the water allowing the bacteria to make contact with all of the wastes. Controls would be provided that would allow for filling, aeration, settling, and decant cycles. During the fill and aerate cycles, the aerators would be energized. They would be de-energized during the settle and decant cycles. Decanters would be provided to drain the clear surface water from the basins after the sludge has settled. This water would be discharged after being disinfected by Ultraviolet light. The controls would alternate basins so that while one basin is being aerated, the other would be settling or decanting. This would reduce the peak flows leaving the plant and being disinfected. For future nutrient removal, the floating aerator/mixers could be used without aeration to mix during an anoxic period and chemical feed equipment can be added at a later date.

During decant, some of the sludge would have to be removed from the basin. Submersible pumps could be used to pump this sludge to the current aeration basin where it could be digested and stored for later removal and land application.

The advantages of an activated sludge conversion include:

- a. Reduced construction footprint by utilizing existing basins.
- b. Extended sludge handling intervals.
- c. High quality effluent.
- d. Some Biological Nitrogen and Phosphorus removal with little or no upgrade costs.

The disadvantages include:

- a. Higher operation and maintenance costs with more aeration.
- b. It is more prone to upset following the introduction of a caustic waste.
- c. Produces higher volumes of sludge to handle

The costs for the activated sludge conversion is shown below:

<u>Item</u>	<u>Description</u>	<u>Units</u>	<u>Unit Cost</u>	<u>Subtotal</u>
1	Earthwork	500 CY	\$ 25.00	\$ 12,500.00
2	Structures - Splitter	1 EA	\$ 30,000.00	\$ 30,000.00
3	BioCurtain	110 LF	\$ 150.00	\$ 16,500.00
4	Retaining Wall	115 CY	\$ 1,000.00	\$ 115,000.00
5	Controls	1 LS	\$ 120,000.00	\$ 120,000.00
6	Decanter	3 EA	\$ 90,000.00	\$ 270,000.00
7	Aerators/Mixers	6 EA	\$ 45,000.00	\$ 270,000.00
8	Misc Piping	1 LS	\$ 80,000.00	\$ 80,000.00
9	Electrical	1 LS	\$ 120,000.00	\$ 120,000.00
10	Gravity Sewer	350 LF	\$ 50.00	\$ 17,500.00
11	Sludge Pumping	2 EA	\$ 40,000.00	\$ 80,000.00
12	Liner	14500 SF	\$ 3.00	\$ 43,500.00
13	UV Disinfection	1 EA	\$ 175,000.00	\$ 175,000.00
14	Sitework	1 Ac	\$ 5,000.00	\$ 5,000.00
15	Discharge Piping	6000 LF	\$ 50.00	\$ 300,000.00
16	Screening	1 EA	\$ 150,000.00	\$ 150,000.00
Total Construction Cost				\$ 1,805,000.00
Engineering Design				\$ 151,000.00
Construction Observation				\$ 113,300.00
Interest				\$ 126,000.00
Legal/Bonding				\$ 20,000.00
Environmental				\$ 7,500.00
Easements				\$ 60,000.00
Contingencies				\$ 181,000.00
TOTAL PROJECT COST				\$ 2,463,800.00

#### 8.2.3.1.2 Conversion to Lagoon with Fixed Film Media

Another process which has shown success in meeting ammonia limits includes the addition a fixed film media to the lagoon based treatment process. This option can be completed in numerous ways and there are several manufacturers trying to sell their version. The various versions include the placement of media pods within the lagoon basin, construction of a submerged media bed after the lagoon, and construction of a recirculating nonsubmerged media filter after the lagoon. Most of these involve additional aeration and could require insulated covers or heaters to maintain a higher water temperature during the winter months.

While similar in the actual biological treatment, the various options do have drastically different operational and maintenance concerns and costs. We feel that the best of these options include insulated covers with a submerged media bed after the lagoon. While heaters could replace the insulated covers, there has not been enough installations to prove this technology as cost efficient yet.

The recommended process would include additional aeration to generate a complete mix zone at the beginning of the plant. All of the lagoon would be covered with insulated floating covers and a fixed film reactor would be placed at the end of the lagoon from which the wastewater would discharge. The reactor is composed of a plastic media stored in a concrete basin. The lagoon effluent flows through the media and aeration is also provided through the media. To help with the lower future mussel based ammonia levels, a recirculating pump station would be constructed after the reactor to recirculate a portion of the treated water back to the lagoon or front of the reactor.

The advantages of covered lagoon with fixed film reactor include:

- a. Reduced construction footprint by utilizing existing basins.
- b. Less susceptible to upset. Stable treatment.
- c. Lengthened sludge handling intervals.
- d. Ease of operation.
- e. High quality effluent.

The disadvantages include:

- a. Higher operation and maintenance costs with more aeration.
- b. Medium construction costs.
- c. Total Nitrogen or Phosphorus removal would require substantial upgrades later.

The costs for the covered lagoon with fixed film reactor conversion is shown below:

Item	Description	Units	Unit Cost	Subtotal
1	Floating Cover	70000 SF	\$ 6.00	\$ 420,000.00
2	Aeration Equipment	1 LS	\$ 550,000.00	\$ 550,000.00
3	Aeration Building	100 SF	\$ 300.00	\$ 30,000.00
4	Baffles	180 LF	\$ 250.00	\$ 45,000.00
5	Reactor Basin	1 LS	\$ 325,000.00	\$ 325,000.00
6	Reactor Media	1 LS	\$ 160,000.00	\$ 160,000.00
7	Disinfection	1 LS	\$ 150,000.00	\$ 150,000.00
8	Recirculation Pump Station	1 LS	\$ 125,000.00	\$ 125,000.00
9	Electrical	1 LS	\$ 45,000.00	\$ 45,000.00
10	Sitework	1 Ac	\$ 5,000.00	\$ 5,000.00
11	Misc. Piping	1 LS	\$ 75,000.00	\$ 75,000.00
12	UV Disinfection	1 LS	\$ 175,000.00	\$ 175,000.00
13	Discharge Piping	6000 LF	\$ 50.00	\$ 300,000.00
Total Construction Cost				\$ 2,405,000.00
Engineering Design				\$ 193,500.00
Construction Observation				\$ 145,100.00
Interest				\$ 125,000.00
Legal/Bonding				\$ 250,000.00
Environmental				\$ 7,500.00
Easements				\$ 60,000.00
Contingencies				\$ 241,000.00
TOTAL PROJECT COST				\$ 3,427,100.00

#### 8.2.3.2 Construction of a New Treatment Plant

Along with conversion of the existing facilities, the Association can opt to construct a totally new facility at the site of the existing lagoons. A new facility would eliminate any issues that the Association has with operating or maintenance of the existing plant. Other than a new lagoon based system which isn't more cost effective than modifications to the existing lagoon, the only real option is an activated sludge process.

##### 8.2.3.2.1 Activated Sludge Treatment Plant

Several options of biological treatment exist including an oxidation ditch, solids contact, sequencing batch reactor, moving bed bioreactor, and membrane bioreactor. All of these incorporate activated sludge requiring extensive aeration needs and can meet the ammonia limits; but, some can meet more stringent limits as well and some have more construction cost than others. The most cost effective option is a sequencing batch reactor. It is able to meet the current limits as well as remove some total nitrogen and total phosphorus. It also incorporates clarification within the aeration basins to provide construction cost savings.



Advantages of this type of plant include the following:

- a. It has a smaller footprint and takes up less land.
- b. It produces the best quality effluent.

Disadvantages of the mechanical plant include the following:

- a. It is more prone to upset following the introduction of a caustic waste.
- b. It produces large volumes of sludge.
- c. It can have higher operating and maintenance costs associated with the handling of sludge.

A mechanical plant would take up less than 1 acre of land and be located at a location in one of the old lagoon cells.

The estimated capital construction costs for a new concrete structured sequencing batch reactor is shown below:

<u>Item</u>	<u>Description</u>	<u>Units</u>	<u>Unit Cost</u>	<u>Subtotal</u>
1	Screening	1 LS	\$ 150,000.00	\$ 150,000.00
2	Grit Removal	1 LS	\$ 150,000.00	\$ 150,000.00
3	Reaction Basins	285 CY	\$ 1,000.00	\$ 285,000.00
4	Aeration Equipment	2 EA	\$ 220,000.00	\$ 440,000.00
5	Aeration Building	300 SF	\$ 300.00	\$ 90,000.00
6	Decant Equipment	2 EA	\$ 45,000.00	\$ 90,000.00
7	Sludge Transfer Pumps	2 EA	\$ 35,000.00	\$ 70,000.00
8	Controls	1 LS	\$ 200,000.00	\$ 200,000.00
9	Electrical	1 LS	\$ 120,000.00	\$ 120,000.00
10	Site Piping	1 LS	\$ 125,000.00	\$ 125,000.00
11	EQ Basin	240 CY	\$ 1,000.00	\$ 240,000.00
12	Site Work	1.00 AC	\$ 5,000.00	\$ 5,000.00
13	UV Disinfection	1 LS	\$ 175,000.00	\$ 175,000.00
14	Discharge Piping	6000 LF	\$ 55.00	\$ 330,000.00
15	Fencing	540 LF	\$ 25.00	\$ 13,500.00
Total Construction Cost				\$ 2,483,500.00
Engineering Design				\$ 199,000.00
Construction Observation				\$ 149,300.00
Interest				\$ 160,000.00
Legal/Bonding				\$ 20,000.00
Environmental				\$ 7,500.00
Easements				\$ 60,000.00
Contingencies				\$ 248,000.00
TOTAL PROJECT COST				\$ 3,327,300.00

### 8.2.3.3 Relocated Discharge Treatment Plant Comparisons

Based upon the above, there are three options recommended for improvements with discharge relocation. Those include new Concrete SBR with discharge relocation, Lagoon Upgrade to SBR with discharge relocation, and Lagoon Upgrade with Fixed Film Media and discharge relocation. Additional cost factors can also be taken into account however, and those are the operation and maintenance of the facilities. The District already has a full time operator for the water and wastewater so labor will not be included in the evaluation. Power, sludge disposal, and repairs will be necessary however.

Below is a chart outlining some of the added operation and maintenance items with their estimated costs:

<u>System Type</u>	<u>Annual Treatment System O&amp;M</u>			<u>Total</u>
	<u>Power</u>	<u>Repl.</u>	<u>Sludge</u>	
New Concrete SBR	\$8,650	\$21,630	\$7,000	\$37,280
SBR Lagoon	\$8,600	\$20,630	\$7,000	\$36,230
Covered Lagoon w/ Fixed Film Reactor	\$6,900	\$16,630	\$7,000	\$30,530

Based upon the estimated construction cost and the operation and maintenance costs, the present worth value can be calculated. This is the total value of the project if all costs were brought to present day values and financed in one lump sum with the future costs placed into an interest bearing account until needed. The present worth of these options at 2.5% (from OMB Circular No. A-94) over 20 years are shown below:

<u>System Type</u>	<u>Construction Cost</u>	<u>Present Worth of Treatment O&amp;M</u>	<u>20-year Project Cost</u>
New Concrete SBR	\$3,327,300	\$580,932	\$3,908,323
SBR Lagoon	\$2,463,800	\$564,760	\$3,028,560
Covered Lagoon w/ Fixed Film Reactor	\$3,427,100	\$475,671	\$3,902,771

Based upon the present worth values, the Lagoon conversion to an SBR is the most cost effective. This option would meet the estimated limits for the alternate receiving stream and would be capable of performing some Total Nitrogen and Phosphorus removal in the future without major upgrades.

### 8.2.4 Maintain the Existing Discharge Location

If no land is available for land application or discharge piping and the District decides that they do not want to relocate their existing facilities, the existing facilities would have to be upgraded to meet the 2022 effluent limits. Upgrades should be made to also meet more stringent limits; but, there is no treatment option would consistently meet the 13 year limits being set.

Per the DNR discussions, we will examine options capable of meeting the 2022 limits. These options can be considered as some of the most technologically advanced treatment methods.

#### 8.2.4.1 Modification of the Existing Aerated Lagoon by conversion to Activated Sludge System

As outlined in the previous section, the existing lagoon could be converted to a Sequencing Batch Reactor. Combined with a tertiary disc filter, it would be capable of meeting the 2022 limits. This option is also capable of some nutrient removal without a substantial upgrade.

The costs for the activated sludge conversion is shown below:

<u>Item</u>	<u>Description</u>	<u>Units</u>	<u>Unit Cost</u>	<u>Subtotal</u>
1	Earthwork	500 CY	\$ 25.00	\$ 12,500.00
2	Structures - Splitter	1 EA	\$ 30,000.00	\$ 30,000.00
3	BioCurtain	110 LF	\$ 150.00	\$ 16,500.00
4	Retaining Wall	115 CY	\$ 1,000.00	\$ 115,000.00
5	Controls	1 LS	\$ 120,000.00	\$ 120,000.00
6	Decanter	3 EA	\$ 90,000.00	\$ 270,000.00
7	Aerators/Mixers	6 EA	\$ 45,000.00	\$ 270,000.00
8	Misc Piping	1 LS	\$ 80,000.00	\$ 80,000.00
9	Electrical	1 LS	\$ 120,000.00	\$ 120,000.00
10	Gravity Sewer	350 LF	\$ 50.00	\$ 17,500.00
11	WAS Sludge Pumping	2 EA	\$ 40,000.00	\$ 80,000.00
12	Liner	14500 SF	\$ 3.00	\$ 43,500.00
13	UV Disinfection	1 EA	\$ 175,000.00	\$ 175,000.00
14	Tertiary Disc Filter	1 LS	\$ 275,000.00	\$ 275,000.00
15	Sitework	1 Ac	\$ 5,000.00	\$ 5,000.00
16	Screening	1 EA	\$ 150,000.00	\$ 150,000.00
Total Construction Cost				\$ 1,780,000.00
Engineering Design				\$ 149,200.00
Construction Observation				\$ 111,900.00
Interest				\$ 120,000.00
Legal/Bonding				\$ 20,000.00
Environmental				\$ 7,500.00
Contingencies				\$ 178,000.00
TOTAL PROJECT COST				\$ 2,366,600.00

#### 8.2.4.2 Construction of a New Treatment Plant

The best form of treatment available would be provided by Reverse Osmosis (RO). This type of plant would not only require an activated sludge treatment as discussed previously; but, also require tertiary treatment, and membrane pretreatment prior to the reverse osmosis membranes. This would basically require a wastewater treatment plant followed by a water treatment plant followed by reverse osmosis.

RO has high construction, operating, and maintenance costs as membranes require high pumping pressures, routine cleaning, and regular membrane replacement.

This form of treatment only treats 75%-90% of the water. The remaining 10%-25% is wasted as a reject stream that is high in the contaminants being removed (they have to go somewhere). Based on a flow of 118,000 gpd, the reject stream would be 12,000 gpd or more. The District would have to find a location for this waste stream. It could not be discharged to Big Bottom Creek with the proposed limits. That waste stream would have to be land applied on unused property around the development.

The costs for this type of system are as follows:

<u>Item</u>	<u>Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Subtotal</u>
<u>SBR</u>				
1	Screening	1 LS	\$ 150,000.00	\$ 150,000.00
2	Grit Removal	1 LS	\$ 150,000.00	\$ 150,000.00
3	Reaction Basins	285 CY	\$ 1,000.00	\$ 285,000.00
4	Aeration Equipment	2 EA	\$ 220,000.00	\$ 440,000.00
5	Aeration Building	300 SF	\$ 300.00	\$ 90,000.00
6	Decant Equipment	2 EA	\$ 45,000.00	\$ 90,000.00
7	Sludge Transfer Pumps	2 EA	\$ 35,000.00	\$ 70,000.00
8	Controls	1 LS	\$ 200,000.00	\$ 200,000.00
9	Electrical	1 LS	\$ 120,000.00	\$ 120,000.00
10	Site Piping	1 LS	\$ 125,000.00	\$ 125,000.00
11	EQ Basin	240 CY	\$ 1,000.00	\$ 240,000.00
12	Site Work	1.00 AC	\$ 5,000.00	\$ 5,000.00
13	UV Disinfection	1 LS	\$ 175,000.00	\$ 175,000.00
14	Fencing	540 LF	\$ 20.00	\$ 10,800.00
<u>UF FILTER</u>				
16	Filter Building	880 SF	\$ 300.00	\$ 264,000.00
17	Filter Equipment	4 EA	\$ 150,000.00	\$ 600,000.00
18	Electrical	1 LS	\$ 30,000.00	\$ 30,000.00
19	Booster & Backwash Pump	4 EA	\$ 35,000.00	\$ 140,000.00
20	Coagulant Equipment	2 EA	\$ 30,000.00	\$ 60,000.00
21	Piping	1 LS	\$ 20,000.00	\$ 20,000.00
<u>REVERSE OSMOSIS</u>				
22	Membrane Building	1200 SF	\$ 300.00	\$ 360,000.00
23	Membrane Equipment	2 EA	\$ 500,000.00	\$ 1,000,000.00
24	Booster Pumping	2 EA	\$ 35,000.00	\$ 70,000.00
25	Wetwell	1 LS	\$ 35,000.00	\$ 35,000.00
26	Electrical	1 LS	\$ 55,000.00	\$ 55,000.00
27	Piping	1 LS	\$ 35,000.00	\$ 35,000.00
<u>REJECT LAND APPLICATION</u>				
28	Excavation/Embankment	6800 CY	\$ 25.00	\$ 170,000.00
29	Land App. Lift Station	1 EA	\$ 150,000.00	\$ 150,000.00
30	Land App. Forcemain	2500 LF	\$ 50.00	\$ 125,000.00
31	Irrigation Guns	10 EA	\$ 6,000.00	\$ 60,000.00
Total Construction Cost				\$ 5,324,800.00
Engineering Design				\$ 384,600.00
Construction Observation				\$ 288,500.00
Interest				\$ 160,000.00
Legal/Bonding				\$ 20,000.00
Environmental				\$ 7,500.00
Electrical Service	4000 LF	\$	40.00	\$ 160,000.00
Contingencies				\$ 532,000.00
TOTAL PROJECT COST				\$ 6,877,400.00

### 8.2.4.3 Existing Discharge Location Comparisons

Based upon the above, there are two options recommended for improvements at the existing location. Those include Lagoon Upgrade to SBR and Reverse Osmosis. Additional cost factors can also be taken into account however, and those are the operation and maintenance of the facilities. The District already has a full time operator for the water and wastewater so labor will not be included in the evaluation. Power, sludge disposal, and repairs will be necessary however.

Below is a chart outlining some of the added operation and maintenance items with their estimated costs:

<u>System Type</u>	<u>Annual Treatment System O&amp;M</u>			<u>Total</u>
	<u>Power</u>	<u>Repl.</u>	<u>Sludge</u>	
SBR Lagoon	\$8,600	\$20,630	\$7,000	\$36,230
Reverse Osmosis	\$8,650	\$30,150	\$7,000	\$45,800

Based upon the estimated construction cost and the operation and maintenance costs, the present worth value can be calculated. This is the total value of the project if all costs were brought to present day values and financed in one lump sum with the future costs placed into an interest bearing account until needed. The present worth of these options at 5% over 20 years are shown below:

<u>System Type</u>	<u>Construction Cost</u>	<u>Present Worth of Treatment O&amp;M</u>	<u>20-year Project Cost</u>
SBR Lagoon	\$2,366,600	\$564,760	\$2,931,360
Reverse Osmosis	\$6,877,400	\$713,440	\$7,590,840

Based upon the present worth values, the Lagoon conversion to an SBR is the most cost effective. This option would meet the 2022 limits and would be capable of performing some Total Nitrogen and Phosphorus removal in the future without major upgrades.

## 8.3 Alternative Comparison

### 8.3.1 Wastewater Collection

Based upon the discussion in Section 8.4.1 above, there are two options recommended for examination as a potential solution to the I/I problems. Those include replacement of the gravity collection system beneath the lake with a pressurized system or partial replacement of the gravity collection system beneath the lake with a new gravity main along the edge of the shoreline. Comparing the present worth values yields the following:

<u>System Type</u>	<u>Construction Cost</u>	<u>Present Worth of Treatment O&amp;M</u>	<u>20-year Project Cost</u>
Pressure System Upgrade	\$3,730,759	\$791,275	\$4,522,034
Gravity System Upgrade	\$3,573,865	\$104,447	\$3,678,312

Based upon the present worth values, the gravity system upgrade is the most cost effective. Not only is it more cost effective, it will be much easier to operate and maintain. If the system is

not maintained effectively, gravity flow can actually reduce the potential for sanitary sewer overflows (SSO's) in the lake and be more environmentally friendly.

### 8.3.2 Wastewater Treatment

Based upon the above, there are three options recommended for further examination as an ultimate solution. Those include Lagoon Upgrade to SBR with discharge relocation to Indian Creek, Lagoon Upgrade to SBR with Tertiary Filtration, and Land Application. Comparing the present worth values yields the following:

<u>System Type</u>	<u>Construction Cost</u>	<u>Present Worth of Treatment O&amp;M</u>	<u>20-year Project Cost</u>
SBR Lagoon to Ind Cr	\$2,463,800	\$564,760	\$3,028,560
SBR Lagoon with Tert. Flt	\$2,366,600	\$564,760	\$2,931,360
Land Application	\$3,984,050	\$277,393	\$4,261,443

Based upon the present worth values, the Lagoon conversion to an SBR is the most cost effective. These options would meet the proposed 6 year limits, meet estimated limits for the alternate receiving stream and would be capable of performing some Total Nitrogen and Phosphorus removal. Land Application is the highest cost (due to the purchase of property); but, it also eliminates the immediate potential for further upgrades being needed. Two of these options are only available if downstream property can be acquired and because the cost for the two SBR options are essentially equal, there is no need to change the discharge location from the existing one so the option of an SBR conversion discharging to Indian Creek will be eliminated.

The construction of the Land application option will also have a negative impact to Big Bottom Creek. While they will lower the nutrient loading to the stream they will also remove all flow from the stream during the summer months. This will essentially eliminate all aquatic life in Big Bottom Creek.

### 8.4 Alternative Recommendation

Since members of the Association have been unsuccessful in finding available ground for a land application system in the past, we will recommend that the existing aerated lagoon be converted into a Sequencing Batch Reactor.

For a SBR modification, the existing polishing cell would be divided into two cells with a concrete wall. During construction the aerated cell effluent could be directed to the old tertiary cell for settling and discharge.

These two new cells would then be converted to aeration basins with the addition of floating aerators and mixers. Calculations show a basin biomass volume needed of approximately 9,000 cubic feet/basin. This would store the biomass and wet weather flows. The proposed basins can hold this volume at a 4.7 feet depth. A safety depth of 3 feet would be placed above this to prevent currents from bringing biomass into the decanter after settling. This sets the low water level at 7.7 feet. During high flows, the water depth in the cells would range from this low level of 7.7 feet to a depth of 8.7 feet. During average flows, it would only rise to 8.2 feet. The existing cell has a water depth of 10 feet with an additional 2 feet of freeboard so no additional depth will need to be added.

Floating decanters would be located at the end opposite of the influent. The influent line would be re-routed to a splitter where the flows would be split to the two basins. Ringlace could be draped across the cell to help provide equal flow distribution and to provide a fixed film surface for bacteria to attach. Control would be incorporated to provide fill, aerate, settle, and decant cycles to treat the water. The aeration cycle could be modified to include anoxic mix for total nutrient removal if needed.

During decant, the water would flow to a small equalization basin that would restrict the exiting flow so that downstream components would not have to be as large. Following this equalization basin, a cloth disk filter would be constructed to filter out additional TSS. This would reduce the TSS levels as well as the BOD levels since a portion of the TSS is organic in nature. It can also help remove additional phosphorus when combined with chemical addition.

After filtration, ultraviolet disinfection will be installed prior to flow measuring and discharge. Flow measuring would be incorporated into the controls to determine cycle lengths and decant flow rates during peak wet weather events as well as to help control the disinfection system.

Sludge wasting pumps would be installed that would cycle on/off to pump settled sludge during the decant cycle. The sludge would be pumped to the existing aeration basin which could be converted to an aerobic digester. A decanter could return the supernatant from the sludge basin to the head of the plant for treatment. This basin will provide enough sludge storage for over 10 years and the Association can then contract to have the sludge removed (pumped or dredged) from this basin and land applied.

The proposed layout for the improvements are shown in Figure 4, *Proposed Collection System Improvements* and Figure 5, *Proposed SBR Lagoon Layout*.



The costs for the recommended improvements are as follows:

*Treatment Improvements*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>		<u>Subtotal</u>
1	Earthwork	500	CY	\$ 25.00	\$	12,500.00
2	Structures - Splitter	1	EA	\$ 30,000.00	\$	30,000.00
3	BioCurtain	110	LF	\$ 150.00	\$	16,500.00
4	Retaining Wall	115	CY	\$ 1,000.00	\$	115,000.00
5	Controls	1	LS	\$ 120,000.00	\$	120,000.00
6	Decanter	3	EA	\$ 90,000.00	\$	270,000.00
7	Aerators/Mixers	6	EA	\$ 45,000.00	\$	270,000.00
8	Misc Piping	1	LS	\$ 80,000.00	\$	80,000.00
9	Electrical	1	LS	\$ 120,000.00	\$	120,000.00
10	Gravity Sewer	350	LF	\$ 50.00	\$	17,500.00
11	WAS Sludge Pumping	2	EA	\$ 40,000.00	\$	80,000.00
12	Liner	14500	SF	\$ 3.00	\$	43,500.00
13	UV Disinfection	1	EA	\$ 175,000.00	\$	175,000.00
14	Tertiary Disc Filter	1	EA	\$ 275,000.00	\$	275,000.00
15	Sitework	1	Ac	\$ 5,000.00	\$	5,000.00
16	Screening	1	EA	\$ 150,000.00	\$	150,000.00
Subtotal Treatment Construction Cost						\$ 1,780,000.00

*Collection System Improvements*

*Lake Anne*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>		<u>Subtotal</u>
1	Excavation & Removal	12600	CY	\$ 25.00	\$	315,000.00
2	8" DIP Gravity Sewer	7050	LF	\$ 100.00	\$	705,000.00
3	Manholes	21	EA	\$ 5,000.00	\$	105,000.00
4	Tie-ins	19	EA	\$ 3,000.00	\$	57,000.00
5	Line Plugs	4	EA	\$ 5,000.00	\$	20,000.00
Subtotal Collection System Cost						\$ 1,202,000.00

*Lake Marian*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>		<u>Subtotal</u>
1	8" DIP Gravity Sewer	5178	LF	\$ 100.00	\$	517,800.00
2	Manholes	16	EA	\$ 5,000.00	\$	80,000.00
3	Tie-ins	12	EA	\$ 3,000.00	\$	36,000.00
Subtotal Collection System Cost						\$ 633,800.00

*Lake Susan*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>		<u>Subtotal</u>
1	8" DIP Gravity Sewer	2088	LF	\$ 100.00	\$	208,800.00
2	Manholes	9	EA	\$ 5,000.00	\$	45,000.00
3	Tie-ins	9	EA	\$ 3,000.00	\$	27,000.00
Subtotal Collection System Cost						\$ 280,800.00

*Sewer Repair*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>		<u>Subtotal</u>
1	Manhole Liners	243	EA	\$ 900.00	\$	218,700.00
2	CIPP Gravity Repair	3310	LF	\$ 50.00	\$	165,500.00
Subtotal Collection System Cost						\$ 384,200.00

#### *Metering*

<u>Item</u>	<u>Description</u>	<u>Units</u>		<u>Unit Cost</u>	<u>Subtotal</u>
1	5/8"x3/4" Meter, Base, Box	300	EA	\$ 900.00	\$ 270,000.00
2	Computer, Software & Support	1	EA	\$ 20,000.00	\$ 20,000.00
Subtotal Metering Cost					\$ 290,000.00
Total Construction Cost					\$ 4,570,800.00
Collection System Inspection					\$ 81,365.00
Engineering Design					\$ 337,000.00
Construction Observation					\$ 252,800.00
Legal					\$ 15,000.00
Closing Costs					\$ 15,000.00
Environmental					\$ 7,500.00
Contingencies					\$ 457,000.00
TOTAL PROJECT COST					\$ 5,736,465.00

## 9. OPTIONS FOR FINANCING

As the District knows, improvements to a wastewater system is a major undertaking for a small group of homeowners, and if the project is to be realized, the homeowners must be willing to bear most if not all of the financial burden of the project.

Because the Association recently formed as a Re-organized Sewer District, there are more financing options available than before.

Following are brief outlines of some of the financing programs and their value to this project.

### 9.1 Community Development Block Grant Program

The Community Development Block Grant Program of the Missouri Department of Economic Development offers grants to low income communities and districts. This grant program provides a maximum grant amount of \$750,000; however, these grants are not typically made unless the improvements will increase the user costs to 2% of the median household income. This will require an average user charge of \$74.18 per month for water based on the 2010 census data. To qualify for these grants, the recipient must have 51% of its residents below the median income level. It is unlikely that the District has a LMI greater than 51% so this grant program is not available.

### 9.2 State Rural Sewer Grant

This program, funded by the Missouri Department of Natural Resources, can provide up to \$1,400 per connection in grant funding with a grant maximum of \$500,000. This program has not been funded in the past several years and funding is not anticipated for several years with the current economy. With 500 connections, the available amount would be \$500,000. These grants are based upon priority points given for need and health concerns. When available, these are hard to obtain as many communities compete for them.

### 9.3 State Revolving Fund

This program, through the State Department of Natural Resources, offers low interest loans. This program has an interest rate of 30% of the AAA municipal market interest rate plus a yearly administration fee of 1% which is set the week when the loan closes. This loan is paid back over 20 years. All eligible systems are placed on the Intended Use Plan unless there is not enough funding available, where they might be placed on a contingency list. Recently, these loans have not been difficult to obtain; however, they do require a bond issue be passed by the voters in the District.

This program also has a Clean Water State Revolving Fund Affordability Grant which can provide up to \$2,000,000 but is limited to 50% of the project cost if the applicant qualifies. Funding is limited so this grant is also competitive and based upon need. This grant requires the recipient to meet certain criteria to be eligible. Those criteria include a population of 3,300 or less, a user charge that will be at or above 2% of the median household income, and a median household income that is at or below 75% of the state average, unemployment rate, poverty rate, and others. Preliminary completion of the online grant eligibility form shows that the District could be eligible for DNR grants. The grant eligibility form is included as Exhibit 2, Grant Eligibility Form.

The application deadline for this program is March 1, 2020. An application, including the preliminary engineering report, would have to be submitted. After submission, the State agency reviews the applications and ranks the projects using priority points based upon need and health concerns. If the project scores high enough, it will be placed upon the state Intended Use Plan which is typically issued in October. After this notification of funding is complete, it typically takes another year before construction can begin on the project.

### 9.4 USDA Rural Development Loan/Grant

The United States Department of Agriculture Rural Development agency has loans and grants available to low income communities. This program is based upon need and income levels of the community. Grants are not typically made unless the improvements will increase the user costs to 2% of the median household income. As with the CDBG Grant, this will require an average user charge of \$74.18 per month for sewer before the grant is made. The amount of grant is typically need driven; but, as the State receives its funding in the form of 70% loan/30% grant monies, they try to keep that ratio as the maximum where possible. The District is eligible for this program.

The loans made at the intermediate rate are currently 2.375% over a 35 year period.

### 9.5 Revenue or General Obligation Bonds

The project can be financed by sale of revenue or general obligation (property tax) bonds. Revenue bonds are backed by revenue generated from the water system. It takes a simple majority of the voters to pass a revenue bond issue.

General Obligation (G.O.) Bonds are backed by property tax levies; however, they can be paid back with revenues from the sewer system. It takes either a four-sevenths or a two-thirds

majority to pass a G.O. bond issue depending on the election date. Because the Owner is a District, they most likely do not have taxing ability and therefore G.O. Bonds are not an option.

Money can be made available from bonds sold on the open market within a very short time frame. If such financing is selected the project could be started as soon as a bond issue is passed and the design completed. The project could be under construction in late 2019.

The interest rates for open market sales are higher than the SRF bonds. Current rates on the open market are around 4.0%. If an bond issue is needed and passed, it would not be fiscally advisable to use the open market when low interest loans such as DNR and USDA are available.

#### 9.6 Lease Financing

Another method of obtaining financing for municipal improvements is through lease financing. In a lease financing arrangement, the District leases the real property (the project site) to a third party and the third party then simultaneously leases the project site together with the improvements back to the District for rental payments that will be sufficient to pay the debt service on the bonds. The third party, which is usually a non-profit corporation (new or existing) or a bank or trust company, obtains the bonds for the project. This form of financing does not require voter approval and may be paid back with revenue from the user rates or a proposition can be taken to the voters to levy new or increased taxes. In certain circumstances, utility rates may be raised without voter approval. This type of financing is typically around 1% higher in interest rates than open market revenue bond rates; but, it is the quickest option for financing.

### 10. RECOMMENDATIONS FOR FINANCING

Because the interest rates between the DNR loans and the USDA loans are not that different and the District could be eligible for grants, it is recommended that applications be made to both. Once the agencies determine grant eligibility, the actual funding agency can be selected.

The DNR application must be submitted by March 1, 2020 in order to be eligible for grants; but, the USDA application can be made at any time.

## 11. LOCAL COSTS

The local costs for the project depend upon the financial vehicle used to pay the project costs.

Besides loan payments, there are other costs associated with the wastewater system that must be included in the monthly user charge.

Below is a listing of annual operation and maintenance, replacement accounts, sludge disposal, billing, etc. costs associated with the system:

Replacement Account	\$ 30,900
Sludge Disposal	\$ 7,000
Operator Costs	\$ 9,000
Additional Manpower	\$ 10,400
Billing/Collections	\$ 6,000
Testing	\$ 6,000
Repairs	\$ 10,000
Fees & Permits	\$ 1,000
Electrical Costs	\$ 9,000
Chemicals	\$ 3,000
Operating Equipment	\$ 2,000
Office Rental	\$ 6,000
Miscellaneous Expenses	<u>\$ 5,000</u>
Total O&M Costs	\$105,300

These costs combined with the financing of the system improvements will determine the total user costs.

### 11.1 No Grant Funds Involved

If no grant funds are involved and the project is funded by 100% loan through USDA, it is estimated that a loan of \$5,750,000 will be taken at an interest rate of 2.375% for a period of 35 years. Such a loan would have an annual payment of \$243,800. A reserve fund must also be set aside with 10% of the payment being placed into it annually. This gives a total annual cost for the system of \$373,500. When split among 280 users, the estimated monthly user charge would be \$111.16. This is 3.0% of the median household income.

### 11.2 Grant Funds Involved

Because of the high user charge based upon 100% loan financing, it is expected that grants can be obtained.

With a grant and loan combination of \$2,300,000 in grants and \$3,450,000 in loans the annual payment would be approximately \$146,300. Combined with the other costs, the total annual cost for the system would be \$266,200. When split among 280 users, the estimated monthly user charge would be \$79.22 which is 2.14% of the median household income.

## 12. RECOMMENDATIONS

It is recommended that this report be reviewed by the District and a decision made on the recommended improvements and guidance provided on the desired finance method.

Once approved by the District, the Engineering Report can be submitted to USDA for review and financing. An anticipated timeline for the project could be as follows:

Submit Report to USDA for funding	01/31/2020
Receive approval and Letter of Intent to fund	06/30/2020
Complete Design	03/31/2021
Obtain DNR & USDA approval of design	09/30/2021
Advertise for Bids	10/31/2021
Begin Construction	01/01/2022
Complete Treatment Plant Construction	12/31/2022
Complete Collection System Construction	06/30/2023

## FIGURES





Data use subject to license.

© 2006 DeLorme. Topo USA® 6.0.

www.delorme.com





Figure 1, Vicinity Map





Data use subject to license.

© 2006 DeLorme. Topo USA® 6.0.

www.delorme.com





Figure 2, Topographic Map





DESIGN INFORMATION:		
AVG. DAILY FLOW	=	0.376 mgd
AVG. DAILY ORGANIC LOAD	=	242 lb BOD/day
PEAK INCOMING FLOW	=	0.640 mgd
CLEAN WATER OXYGEN DEM'T	=	484 lb O2/day
DESIGN INFORMATION:		
PARAMETER	MONTHLY AVG.	WEEKLY AVG.
BOD , mg/l	30	--
SS , mg/l	60	--

SANITARY SEWER LAGOON IMPROVEMENTS		FIGURE 3
LAKE FOREST SUBDIVISION		
EXISTING LAGOON SITE PLAN		
WATERS ENGINEERING, INC.		REVISIONS:
Civil Engineering & Surveying P. O. Box 567 908 S. Kingshighway Sikeston, Missouri 63801 E-Mail: main@waterseng.com		




Figure 4, PROPOSED COLLECTION SYSTEM IMPROVEMENTS





## **EXHIBITS**

STATE OF MISSOURI  
DEPARTMENT OF NATURAL RESOURCES  
MISSOURI CLEAN WATER COMMISSION



**MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No.	MO-0035742
Owner:	Lake Forest Estates Community Association
Address:	13765 Lakewood Drive, Ste. Genevieve, MO 63670
Continuing Authority:	Same as above
Address:	Same as above
Facility Name:	Lake Forest Estates Subdivision WWTF
Facility Address:	0.6 miles northeast of Hwy O and Lakewood Dr. intersection, Ste. Genevieve, MO 63670
Legal Description:	See Page 2
UTM Coordinates:	See Page 2
Receiving Stream:	See Page 2
First Classified Stream and ID:	See Page 2
USGS Basin & Sub-watershed No.:	See Page 2

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

**FACILITY DESCRIPTION**

See Page 2

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 621.250 RSMo, Section 640.013 RSMo and Section 644.051.6 of the Law.

<u>February 1, 2016</u>	<u>February 17, 2017</u>
Effective Date	Modification Date


Steven Feeler, Acting Director, Division of Environmental Quality

<u>January 31, 2021</u>
Expiration Date


David J Lamb, Acting Director, Water Protection Program

**FACILITY DESCRIPTION (continued):**

Outfall #001 – Residential Subdivision – SIC #8641

Three-cell lagoon with baffled and aerated 1<sup>st</sup> and 2<sup>nd</sup> cells / three cell flow equalization basin / sludge retained in lagoon

Design population equivalent is 1,040.

Design flow is 118,300 gallons per day.

Actual flow is 99,300 gallons per day.

Design sludge production is 15.6 dry tons/year.

Legal Description:	Landgrant 2046, Ste. Genevieve County
UTM Coordinates:	X=745263, Y=4204623
Receiving Stream:	Big Bottom Creek (C)
First Classified Stream and ID:	Big Bottom Creek (C) (1746)
USGS Basin & Sub-watershed No.:	(07140101-0907)

Permitted Feature #SM1 – Instream Monitoring

Instream monitoring location – Upstream – See Special Condition #20

Receiving Stream:	Big Bottom Creek (C)
First Classified Stream and ID:	Big Bottom Creek (C) (1746)
USGS Basin & Sub-watershed No.:	(07140101-0907)

Permitted Feature #SM2 – Instream Monitoring

Instream monitoring location – Downstream – approximately 75 meters downstream from Outfall #001 – See Special Condition #20

Legal Description:	Landgrant 2046, Ste. Genevieve County
UTM Coordinates:	X=745257, Y=4204686
Receiving Stream:	Big Bottom Creek (C)
First Classified Stream and ID:	Big Bottom Creek (C) (1746)
USGS Basin & Sub-watershed No.:	(07140101-0907)



OUTFALL #001	TABLE A-1. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				PAGE NUMBER 3 of 9	
					PERMIT NUMBER MO-0035742	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective on <b>February 1, 2016</b> , and remain in effect through <b>January 31, 2022</b> . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Flow	MGD	*		*	twice/week	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		60	30	once/month	grab
Total Suspended Solids	mg/L		60	30	once/month	grab
Ammonia as N (Apr 1 – Sep 30) (Oct 1 – Mar 31)	mg/L	3.7 7.5		1.9 3.7	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2016</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE		QUARTERLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Total Phosphorus	mg/L	*		*	once/quarter	grab
Total Nitrogen	mg/L	*		*	once/quarter	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>APRIL 28, 2016</u> .						
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units **	SU	6.5			once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2016</u> .						



OUTFALL #001	TABLE A-2. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				PAGE NUMBER 4 of 9	
					PERMIT NUMBER MO-0035742	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective on <b>February 1, 2022</b> , and remain in effect through <b>January 31, 2029</b> . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Flow	MGD	*		*	twice/week	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		15	10	once/month	grab
Carbonaceous Biochemical Oxygen Demand <sub>5</sub>	mg/L		*	*	once/month	grab
Nitrogenous Biochemical Oxygen Demand <sub>5</sub> (Note 1, Page 5)	mg/L		*	*	once/month	calculated
Total Suspended Solids (Final)	mg/L		15	10	once/month	grab
<i>E. coli</i> (Note 2, Page 5)	#/100mL	1030		206	once/week	grab
Ammonia as N (Apr 1 – Sep 30) (Oct 1 – Mar 31)	mg/L	2.4 6.9		0.6 2.1	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2022</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE		QUARTERLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Total Phosphorus	mg/L	*		*	once/month	grab
Total Nitrogen	mg/L	*		*	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2022</u> .						
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units **	SU	6.5		9.0	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2022</u> .						
EFFLUENT PARAMETER(S)	UNITS	DAILY MINIMUM		MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Dissolved Oxygen	mg/L	*		*	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2022</u> .						

OUTFALL #001	TABLE A-3. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				PAGE NUMBER 5 of 9	
					PERMIT NUMBER MO-0035742	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective on <b>February 1, 2029</b> , and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Flow	MGD	*		*	twice/week	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		*	*	once/month	grab
Carbonaceous Biochemical Oxygen Demand <sub>5</sub>	mg/L		7.56	5.04	once/month	grab
Nitrogenous Biochemical Oxygen Demand <sub>5</sub> (Note 1, Page 5)	mg/L		2.19	1.46	once/month	calculated
Total Suspended Solids	mg/L		15	10	once/month	grab
<i>E. coli</i> (Note 2, Page 5)	#/100mL	1030		206	once/week	grab
Ammonia as N	mg/L	1.0		0.3	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2029</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE		QUARTERLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Total Phosphorus	mg/L	*		0.007	once/month	grab
Total Nitrogen	mg/L	*		0.289	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>APRIL 28, 2029</u> .						
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units **	SU	6.5		9.0	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2029</u> .						
EFFLUENT PARAMETER(S)	UNITS	DAILY MINIMUM		MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Dissolved Oxygen	mg/L	8.0		8.0	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MARCH 28, 2029</u> .						

PERMITTED FEATURES #SM1 & #SM2	TABLE B-1. INSTREAM MONITORING REQUIREMENTS	PAGE NUMBER 6 of 9
		PERMIT NUMBER MO-0035742

The monitoring requirements shall become effective on **February 28, 2016**, and remain in effect until expiration of the permit.

PARAMETER(S)	UNITS	MONITORING REQUIREMENTS				
		DAILY MAXIMUM		MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Temperature	°C	*		*	once/month	measured
Ammonia as N	mg/L	*		*	once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED **MONTHLY**; THE FIRST REPORT IS DUE **MARCH 28, 2016**.

PARAMETER(S)	UNITS	DAILY MINIMUM		MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Dissolved Oxygen	mg/L	*		*	once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED **MONTHLY**; THE FIRST REPORT IS DUE **MARCH 28, 2016**.

PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units	SU	*		*	once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED **MONTHLY**; THE FIRST REPORT IS DUE **MARCH 28, 2016**.

\* Monitoring requirement only.

\*\* pH is measured in pH units and is not to be averaged.

Note 1 - Nitrogenous Biochemical Oxygen Demand<sub>5</sub> is calculated as the difference between BOD<sub>5</sub> and CBOD<sub>5</sub>.  

$$NBOD_5 = BOD_5 - CBOD_5$$

Note 2 - Effluent limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a geometric mean.

### C. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached **Parts I & III** standard conditions dated **August 1, 2014 and March 1, 2015**, and hereby incorporated as though fully set forth herein.

### D. SPECIAL CONDITIONS

- This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - controls any pollutant not limited in the permit.
  - Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.
  - Incorporate the requirement to develop a pretreatment program pursuant to 40 CFR 403.8(a) when the Director of the Water Protection Program determines that a pretreatment program is necessary due to any new introduction of pollutants into the Publicly Owned Treatment Works or any substantial change in the volume or character of pollutants being introduced.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

- All outfalls must be clearly marked in the field.
- Permittee will cease discharge by connection to a facility with an area-wide management plan per 10 CSR 20-6.010(3)(B) within 90 days of notice of its availability.

D. SPECIAL CONDITIONS (continued)

5. Water Quality Standards

- (a) To the extent required by law, discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
  - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
  - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
  - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
  - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
  - (5) There shall be no significant human health hazard from incidental contact with the water;
  - (6) There shall be no acute toxicity to livestock or wildlife watering;
  - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
  - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

7. Report as no-discharge when a discharge does not occur during the report period.

8. Reporting of Non-Detects:

- (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.
- (b) The permittee shall not report a sample result as "Non-Detect" without also reporting the detection limit of the test. Reporting as "Non Detect" without also including the detection limit will be considered failure to report, which is a violation of this permit.
- (c) The permittee shall provide the "Non-Detect" sample result using the less than sign and the minimum detection limit (e.g. <10).
- (d) The permittee shall use one-half of the detection limit for the non-detect result when calculating monthly averages.
- (e) See Standard Conditions Part I, Section A, #4 regarding proper detection limits used for sample analysis.

9. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).

- 10. Bypasses are not authorized at this facility unless they meet the criteria in 40 CFR 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 CFR 122.41(m)(3)(i), and with Standard Condition Part I, Section B, subsection 2.b. Bypasses are to be reported to the Southeast Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
- 11. The facility must be sufficiently secured to restrict entry by children, livestock and unauthorized persons as well as to protect the facility from vandalism.
- 12. At least one gate must be provided to access the wastewater treatment facility and provide for maintenance and mowing. The gate shall remain locked except when opened by the permittee to perform operational monitoring, sampling, maintenance, mowing, or for inspections by the Department.
- 13. At least one (1) warning sign shall be placed on each side of the facility enclosure in such positions as to be clearly visible from all directions of approach. There shall also be one (1) sign placed for every five hundred feet (500') (150 m) of the perimeter fence. A sign shall also be placed on each gate. Minimum wording shall be SEWAGE TREATMENT FACILITY—KEEP OUT. Signs shall be made of durable materials with characters at least two inches (2") high and shall be securely fastened to the fence, equipment or other suitable locations.

D. SPECIAL CONDITIONS (continued)

14. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.
15. An all-weather access road shall be provided to the treatment facility.
16. The discharge from the wastewater treatment facility shall be conveyed to the receiving stream via a closed pipe or a paved or rip-rapped open channel. Sheet or meandering drainage is not acceptable. The outfall sewer shall be protected against the effects of floodwater, ice or other hazards as to reasonably insure its structural stability and freedom from stoppage. The outfall shall be maintained so that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
17. A minimum of two (2) feet freeboard must be maintained in each lagoon cell. A lagoon level gauge, which clearly marks the minimum freeboard level, shall be provided in each lagoon cell.
18. The berms of the lagoons shall be mowed and kept free of any deep-rooted vegetation, animal dens, or other potential sources of damage to the berms.
19. The facility shall ensure that adequate provisions are provided to prevent surface water intrusion into the lagoons and to divert stormwater runoff around the lagoons and protect embankments from erosion.
20. Receiving Water Monitoring Conditions
  - (a) Downstream receiving water samples should be taken at the location(s) specified on Page 2 of this permit. In the event that a safe, accessible location is not present at the location listed, a suitable location can be negotiated with the Department. Samples should be taken at least four feet from the bank or from the middle of the stream (whichever is less) and 6-inches below the surface. The upstream receiving water sample should be collected at a point upstream from any influence of the effluent, where the water is visibly flowing down stream.
  - (b) When conducting in-stream monitoring, the permittee shall record observations that include: the time of day, weather conditions, unusual stream characteristics (e.g., septic conditions, algae growth, etc.), the stream segment (e.g., riffle, pool or run) from where the sample was collected. These observations shall be submitted with the sample results.
  - (c) Samples shall not be collected from areas with especially turbulent flow, still water or from the stream bank, unless these conditions are representative of the stream reach or no other areas are available for sample collection. Sampling should not be made when significant precipitation has occurred recently. The sampling event should be terminated and rescheduled if any of the following conditions occur:
    - If turbidity in the stream increases notably; or
    - If rainfall over the past two weeks exceeds 2.5 inches or exceeds 1 inch in the last 24 hours
  - (d) Always use the correct sampling technique and handling procedure specified for the parameter of interest. Please refer to the latest edition of Standard Methods for the Examination of Water and Wastewater for further discussion of proper sampling techniques. All analyses must be conducted in accordance with an approved EPA method. Meters shall be calibrated immediately (within 1 hour) prior to the sampling event.
  - (e) To obtain accurate measurements, Dissolved Oxygen and pH analyses should be performed on-site in the receiving stream where possible. However, due to high flow conditions, access, etc., it may be necessary to collect a sample in a bucket or other container. When this is necessary, care must be taken not to aerate the sample upon collection. If for any reason samples must be collected from an alternate site from the one listed in the permit, the permittee shall report the location with the sample results.
  - (f) Dissolved Oxygen measurements are to be taken during the period from one hour prior to sunrise to one and one-half hour after sunrise.
  - (g) Please contact the Department if you need additional instructions or assistance.

D. SPECIAL CONDITIONS (continued)

21. Electronic Discharge Monitoring Report (eDMR) Submission System.

- (a) **Discharge Monitoring Reporting Requirements.** The permittee must electronically submit compliance monitoring data via the eDMR system. In regards to Standard Conditions Part I, Section B, #7, the eDMR system is currently the only Department approved reporting method for this permit.
- (b) **Programmatic Reporting Requirements.** The following reports (if required by this permit) must be electronically submitted as an attachment to the eDMR system until such a time when the current or a new system is available to allow direct input of the data:
  - (1) Schedule of Compliance Progress Reports;
  - (2) Sludge/Biosolids Annual Reports;
  - (3) Any additional report required by the permit excluding bypass reporting.After such a system has been made available by the department, required data shall be directly input into the system by the next report due date.
- (c) **Other actions.** The following shall be submitted electronically after such a system has been made available by the department:
  - (1) Notices of Termination (NOTs);
  - (2) Bypass reporting, See Special Condition #10 for 24-hr. bypass reporting requirements.
- (d) **Electronic Submissions.** To access the eDMR system, use the following link in your web browser: <https://edmr.dnr.mo.gov/edmr/E2/Shared/Pages/Main/Login.aspx>.
- (e) **Waivers from Electronic Reporting.** The permittee must electronically submit compliance monitoring data and reports unless a waiver is granted by the department in compliance with 40 CFR Part 127. The permittee may obtain an electronic reporting waiver by first submitting an eDMR Waiver Request Form: <http://dnr.mo.gov/forms/780-2692-f.pdf>. The department will either approve or deny this electronic reporting waiver request within 120 calendar days. Only permittees with an approved waiver request may submit monitoring data and reports on paper to the Department for the period that the approved electronic reporting waiver is effective.

E. SCHEDULE OF COMPLIANCE

The facility shall attain compliance with interim effluent limitations for Biochemical Oxygen Demand<sub>5</sub> and Ammonia as soon as reasonably achievable or no later than **6 years** of the effective date of this permit.

The facility shall attain compliance with final effluent limitations for Total Suspended Solids and E. coli as soon as reasonably achievable or no later than **6 years** of the effective date of this permit.

The facility shall attain compliance with final effluent limitations for Carbonaceous Biochemical Oxygen Demand<sub>5</sub>, Nitrogenous Biochemical Oxygen Demand<sub>5</sub>, Total Nitrogen, Total Phosphorus, Ammonia, Total Suspended Solids, and Dissolved Oxygen as soon as reasonably achievable or no later than **13 years** of the effective date of this permit.

- 1. Within six months of the effective date of this permit, the permittee shall report progress made in attaining compliance with the final effluent limits.
- 2. The permittee shall submit interim progress reports detailing progress made in attaining compliance with the final effluent limits every 12 months from effective date.
- 3. Within **6 years** of the effective date of this permit, the permittee shall attain compliance with the interim effluent limits for Biochemical Oxygen Demand<sub>5</sub> and Ammonia, and the final effluent limits for E. coli, and Total Suspended Solids.
- 4. Within **13 years** of the effective date of this permit, the permittee shall attain compliance with the final effluent limits, for Carbonaceous Biochemical Oxygen Demand<sub>5</sub>, Nitrogenous Biochemical Oxygen Demand<sub>5</sub>, Total Nitrogen, Total Phosphorus, Ammonia, Total Suspended Solids, and Dissolved Oxygen.

Please submit progress reports to the Missouri Department of Natural Resources, Southeast Regional Office, 2155 North Westwood Boulevard, Poplar Bluff, MO 63901.

**MISSOURI DEPARTMENT OF NATURAL RESOURCES  
EDMR STATEMENT OF BASIS  
MO-0035742**

**LAKE FOREST ESTATES SUBDIVISION WASTEWATER TREATMENT FACILITY**

This Statement of Basis gives pertinent information regarding an internal minor permit modification to the above listed operating permit without the need for a public comment process. A statement of basis is not an enforceable part of a Missouri State Operating Permit.

**Part I – Facility Information**

Facility Type: Residential Subdivision  
Facility SIC Code(s): #8641  
Facility Description:

Three-cell lagoon with baffled and aerated 1<sup>st</sup> and 2<sup>nd</sup> cells / three cell flow equalization basin / sludge retained in lagoon  
Design population equivalent is 1,040.  
Design flow is 118,300 gallons per day.  
Actual flow is 99,300 gallons per day.  
Design sludge production is 15.6 dry tons/year.

**Part II – Modification Rationale**

This operating permit was modified by adding a special condition to the permit to require the permittee to submit all discharge monitoring reports electronically (eDMR) to the department. The final rule (eReporting Rule) substitutes electronic reporting for paper-based reports and, over the long term, saves time and resources for permittees, states, tribes, territories, and EPA, while improving compliance and better protecting the Nation's waters. The final rule requires permittees and regulators to use existing, available information technology to electronically report information and data related to the NPDES permit program in lieu of filing paper-based reports. All authorized programs are required to electronically transmit the federally-required data (identified in appendix A to 40 CFR part 127) to EPA. The purpose and need for this rule was highlighted in the development of the Clean Water Act Enforcement Action Plan (Plan).

Announced by EPA in October 2009, the Plan was a collaborative effort by EPA and state environmental agencies to explore opportunities to improve water quality by emphasizing and adopting new approaches that will improve how the NPDES permitting and enforcement program is administered. The goals of the Plan include improving transparency of the information on compliance and enforcement activities in each state, connecting this information to local water quality, and providing the public with real-time, easy access to this information.

No other changes were made at this time to this permit.

**Part III – Administrative Requirements**

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit.

**DATE OF STATEMENT OF BASIS: FEBRUARY 7, 2017**

**COMPLETED BY:**

**SAMANTHA OSTMANN, ENVIRONMENTAL SPECIALIST  
MISSOURI DEPARTMENT OF NATURAL RESOURCES  
WATER PROTECTION PROGRAM  
INDUSTRIAL UNIT  
(573) 526-2445  
Samantha.Ostmann@dnr.mo.gov**

**MISSOURI DEPARTMENT OF NATURAL RESOURCES  
FACT SHEET  
FOR THE PURPOSE OF RENEWAL  
OF  
MO-0035742  
LAKE FOREST ESTATES SUBDIVISION WWTF**

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollution Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)2.] a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Minor.

**Part I – Facility Information**

Facility Type: NON-POTW – Residential Subdivision – SIC #8641

**Facility Description:**

Three-cell lagoon with baffled and aerated 1<sup>st</sup> and 2<sup>nd</sup> cells / three cell flow equalization basin / sludge retained in lagoon

Have any changes occurred at this facility or in the receiving water body that effects effluent limit derivation?

☒ - Yes; A TMDL was completed by the EPA in 2010 which requires implementation of new effluent limits. Also, the outfall is less than 2 miles from Indian Creek, which is designated as a Whole Body Contact - B stream. Therefore, effluent limits for *E. coli* for WBC-B streams were added to the permit.

☐ - No

Application Date: 05/28/2009

Expiration Date: 11/30/2009

**OUTFALL(S) TABLE:**

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE
#001	0.15	Equivalent to Secondary	Domestic

**Facility Performance History:**

The facility failed to meet Ammonia as N limits on the January, April, May, June, July, and December 2010, February, March, April, May, June, October, and December 2011, January, February, March, April, May, September, October, November, and December 2012, January, February, May, June, and September 2013, January, February, March, April, May, June, November, and December 2014 Discharge Monitoring Reports (DMR). The facility also failed to meet BOD limits on the April 2011, October 2012, October 2013, April and May 2014 DMRs. The facility failed to meet TSS limits on the February 2010 and March 2013 DMRs. The facility failed to submit the March 2010 DMR. This facility was last inspected on May 30, 2013. The inspection showed the following unsatisfactory features; the facility failed to meet effluent limitations on DMRs.

**Comments:**

Changes in this permit include the addition of CBOD<sub>5</sub>, NBOD<sub>5</sub>, Total Nitrogen, Total Phosphorus, and *E. coli*, and the removal of Temperature. See Part VII of the Fact Sheet for further information regarding the addition and removal of effluent parameters. Special conditions were updated to include the reporting of Non-detects, bypass reporting requirements, lagoon cell depth gauges, and the addition of instream monitoring requirements.



## **Part II – Operator Certification Requirements**

- ☐ - This facility is required to have a certified operator.
- ☒ - This facility is not required to have a certified operator.

## **Part III– Operational Monitoring**

- ☒ - As per [10 CSR 20-9.010(4)], the facility is not required to conduct operational monitoring.
- ☐ - As per [10 CSR 20-9.010(4)], the facility is required to conduct operational monitoring.

## **Part IV – Receiving Stream Information**

10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and/or 1<sup>st</sup> classified receiving stream's beneficial water uses to be maintained, are located in the Receiving Stream Table located below in accordance with [10 CSR 20-7.031(4)].

**RECEIVING STREAM(S) TABLE: OUTFALL #001**

WATER-BODY NAME	CLASS	WBID	DESIGNATED USES*	12-DIGIT HUC	DISTANCE TO CLASSIFIED SEGMENT (MI)
Big Bottom Creek	C	1746	IRR, LWW, AQL, HHP, SCR	07140101-0907	0
Indian Creek	C	1747	IRR, LWW, AQL, HHP, WBC-B, SCR		1.1

\* - Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life (AQL), Human Health Protection (HHP), Cool Water Fishery (CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation – Category A (WBC-A), Whole Body Contact Recreation – Category B (WBC-B), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND), Groundwater (GRW).

**RECEIVING STREAM(S) LOW-FLOW VALUES:**

RECEIVING STREAM (C, E, P, P1)	LOW-FLOW VALUES (CFS)		
	1Q10	7Q10	30Q10
Big Bottom Creek (C)	0	0	0

## **MIXING CONSIDERATIONS**

**MIXING CONSIDERATIONS TABLE:**

MIXING ZONE (CFS) [10 CSR 20-7.031(5)(A)...]			ZONE OF INITIAL DILUTION (CFS) [10 CSR 20-7.031(5)(A)...]		
1Q10	7Q10	30Q10	1Q10	7Q10	30Q10
0	0	0	0	0	N/A

## **RECEIVING STREAM MONITORING REQUIREMENTS:**

**Permitted Feature SM1.** (Upstream)

**Permitted Feature SM2.** (Downstream)

## **Receiving Water Body's Water Quality**

No low flow surveys have been conducted on the receiving stream. Big Bottom Creek is an impaired stream and in 2010 EPA approved a TMDL for the stream.

## **Part V – Rationale and Derivation of Effluent Limitations & Permit Conditions**

### **ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:**

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

- ☐ - The facility discharges to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)].
- ☒ - The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)], or is an existing facility.

### **ANTI-BACKSLIDING:**

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(o); 40 CFR Part 122.44(l)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- ☒ - All limits in this operating permit are at least as protective as those previously established; therefore, backsliding does not apply.

### **ANTIDEGRADATION:**

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. Degradation is justified by documenting the socio-economic importance of a discharging activity after determining the necessity of the discharge.

- ☒ - No degradation proposed and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.
- ☐ - This permit contains new and/or expanded discharge; please see **APPENDIX FOR ANTIDEGRADATION ANALYSIS**.

### **AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:**

As per [10 CSR 20-6.010(3)(B)], ...An applicant may utilize a lower preference continuing authority by submitting, as part of the application, a statement waiving preferential status from each existing higher preference authority, providing the waiver does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the Department.

### **BIOSOLIDS & SEWAGE SLUDGE:**

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works. Additional information regarding biosolids and sludge is located at the following web address: <http://extension.missouri.edu/main/DisplayCategory.aspx?C=74>, items WQ422 through WQ449.

- ☐ - Permittee land applies biosolids in accordance with Standard Conditions III and a Department approved biosolids management plan.
- ☒ - Permittee is not authorized to land apply biosolids. Sludge/biosolids are stored in the lagoon. The permittee must submit a sludge management plan for approval that details removal and disposal plans when sludge is to be removed from lagoons.

### **COMPLIANCE AND ENFORCEMENT:**

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

- ☐ - The facility is currently under enforcement action.
- ☒ - The facility is not currently under Water Protection Program enforcement action.

**PRETREATMENT PROGRAM:**

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

☒ - The permittee, at this time, is not required to have a Pretreatment Program or does not have an approved pretreatment program.

**REASONABLE POTENTIAL ANALYSIS (RPA):**

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(1)(iii)] if the permit writer determines that any given pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

☐ - A RPA was conducted on Ammonia as N.

☒ - A RPA was not conducted for this facility.

**REMOVAL EFFICIENCY:**

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD<sub>5</sub>) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals.

☐ - Secondary Treatment is 85% removal [40 CFR Part 133.102(a)(3) & (b)(3)].

☐ - Equivalent to Secondary Treatment is 65% removal [40 CFR Part 133.105(a)(3) & (b)(3)].

☒ - Influent monitoring is not being required to determine percent removal.

**SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):**

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(11)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur.

☒ - This facility is not required to develop or implement a program for maintenance and repair of the collection system; however, it is a violation of Missouri State Environmental Laws and Regulations to allow untreated wastewater to discharge to waters of the state.

**SCHEDULE OF COMPLIANCE (SOC):**

Per 644.051.4 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation. A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 CFR §122.2. For new effluent limitations, the permit includes interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 CFR § 122.47(a)(1) and 10 CSR 20-7.031(11), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

A SOC is not allowed:

- For effluent limitations based on technology-based standards established in accordance with federal requirements, if the deadline for compliance established in federal regulations has passed. 40 CFR § 125.3.
- For a newly constructed facility in most cases. Newly constructed facilities must meet applicable effluent limitations when discharge begins, because the facility has installed the appropriate control technology as specified in a permit or antidegradation review. A SOC is allowed for a new water quality based effluent limit that was not included in a previously public noticed permit or antidegradation review, which may occur if a regulation changes during construction.
- To develop a TMDL, UAA, or other study associated with development of a site specific criterion. A facility is not prohibited from conducting these activities, but a SOC may not be granted for conducting these activities.

In order to provide guidance to Permit Writers in developing SOC's, and attain a greater level of consistency, on October 25, 2012 the Department issued a policy on development of SOC's. This policy provides guidance to Permit Writers on the standard time frames for schedules for common activities, and guidance on factors that may modify the length of the schedule such as an affordability analysis.

☒ - The time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(11)]. The facility has been given a schedule of compliance to meet final effluent limits for Ammonia as N, CBOD<sub>5</sub>, NBOD<sub>5</sub>, TSS, E. coli, Total Nitrogen, Total Phosphorus, and Dissolved Oxygen. Due to the current limitations of technology, achieving compliance with the final effluent limitations will be difficult and will have a high cost, the facility is being provided a 2-phased schedule of compliance.

The first phase will allow a six (6) year schedule of compliance for the facility to meet the 2<sup>nd</sup> interim limits for BOD, TSS, E. coli, and Ammonia. The six year schedule of compliance allowed for this facility should provide adequate time to evaluate operations, obtain an engineering report, obtain funding, obtain a construction permit and implement upgrades required to meet the interim effluent limits. The facility should consider alternative solutions when evaluating how to meet the final effluent limitations. In addition to upgrading the facility, the facility should consider whether relocating the outfall location to a different receiving stream, such as Indian Creek, approximately 0.7 miles northeast of the facility, or Lake Forest, which is located approximately 0.2 miles south of the facility, would be financially feasible. Indian Creek and Lake Forest are not impaired waterways, and the facility would be required to upgrade to meet the applicable BOD<sub>5</sub>, TSS, Ammonia and E. coli effluent limitations, but not to meet the TMDL requirements. After the upgrades are installed during the first phase and a recovery period for the stream, the Department will review the receiving stream to determine if the upgrades have allowed the stream to regain its designated uses.

After completion of the first phase of the schedule of compliance and if the streams designated uses have not been re-attained, the second phase of the schedule of compliance will allow seven (7) years for the facility to meet final limits for Ammonia as N, CBOD<sub>5</sub>, NBOD<sub>5</sub>, TSS, Total Nitrogen, Total Phosphorus, and Dissolved Oxygen. The seven year schedule of compliance should; provide adequate time for stream recovery after the facility has upgraded to meet the 2<sup>nd</sup> interim effluent limits, time for the Department to conduct a re-evaluation of the stream regarding use attainment, allow the Department to re-categorize the stream on the 305b report for approval by the EPA in 2026 if the stream has re-attained uses, allow the facility to evaluate operations, obtain an engineering report, obtain funding, obtain a construction permit and implement any further upgrades required to meet the final effluent limits if it is determined that the stream did not re-attain uses.

**STORMWATER POLLUTION PREVENTION PLAN (SWPPP):**

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; (2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's *Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators*, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in February 2009], BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of stormwater discharges.

☒ - At this time, the permittee is not required to develop and implement a SWPPP.

**VARIANCE:**

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

☐ - This operating permit is drafted under premises of a petition for variance. Please provide a brief summary of the variance as provided in the variance application. Also include if the variance was approved or denied and date of either the approval or denial. Staff can also give reason for the denial if applicable.

☒ - This operating permit is not drafted under premises of a petition for variance.

**WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:**

As per [10 CSR 20-2.010(78)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

☒ - Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$C_e = \frac{(Q_e + Q_s)C - (C_s \times Q_s)}{(Q_e)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration      C<sub>e</sub> = effluent concentration  
Cs = upstream concentration      Q<sub>e</sub> = effluent flow  
Q<sub>s</sub> = upstream flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

**Number of Samples "n":**

Additionally, in accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance, which should be, at a minimum, be targeted to comply with the values dictated by the WLA. Therefore, it is recommended that the actual planned frequency of monitoring normally be used to determine the value of "n" for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for "n" must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is "n = 4" at a minimum. For Total Ammonia as Nitrogen, "n = 30" is used

**WLA MODELING:**

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

☐ - A WLA study including model was submitted to the Department.

☒ - WLA's were provided in the EPA approved TMDL.

**WATER QUALITY STANDARDS:**

Per [10 CSR 20-7.031(4)], General Criteria shall be applicable to all waters of the state at all times including mixing zones. Additionally, [40 CFR 122.44(d)(1)] directs the Department to establish in each NPDES permit to include conditions to achieve water quality established under Section 303 of the Clean Water Act, including State narrative criteria for water quality.

**WHOLE EFFLUENT TOXICITY (WET) TEST:**

☐ - The permittee is required to conduct WET test for this facility.

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Under the federal Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System (NPDES). WET testing is also required by 40 CFR 122.44(d)(1). WET testing ensures that the provisions in the 10 CSR 20-6.010(8)(A)7. and the Water Quality Standards 10 CSR 20-7.031(4)(D),(F),(G),(I)2.A & B are being met. Under [10 CSR 20-6.010(8)(A)4], the Department may require other terms and conditions that it deems necessary to assure compliance with the Clean Water Act and related regulations of the Missouri Clean Water Commission. In addition the following MCWL apply: §§644.051.3 requires the Department to set permit conditions that comply with the MCWL and CWA; 644.051.4 specifically references toxicity as an item we must consider in writing permits (along with water quality-based effluent limits, pretreatment, etc...); and 644.051.5 is the basic authority to require testing conditions. WET test will be required by facilities meeting the following criteria:

- ☐ Facility is a designated Major.
- ☐ Facility continuously or routinely exceeds its design flow.
- ☐ Facility that exceeds its design population equivalent (PE) for BOD<sub>5</sub> whether or not its design flow is being exceeded.
- ☐ Facility (whether primarily domestic or industrial) that alters its production process throughout the year.
- ☐ Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
- ☐ Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH<sub>3</sub>)
- ☐ Facility is a municipality with a Design Flow ≥ 22,500 gpd.
- ☐ Other – please justify.

☒ - At this time, the permittee is not required to conduct WET test for this facility.

**40 CFR 122.41(M) - BYPASSES:**

The federal Clean Water Act (CWA), Section 402 prohibits wastewater dischargers from "bypassing" untreated or partially treated sewage (wastewater) beyond the headworks. A bypass is defined as an intentional diversion of waste streams from any portion of a treatment facility, [40 CFR 122.41(m)(1)(i)]. Additionally, Missouri regulation 10 CSR 20-7.015(9)(G) states a bypass means the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending, to waters of the state. Only under exceptional and specified limitations do the federal regulations allow for a facility to bypass some or all of the flow from its treatment process. Bypasses are prohibited by the CWA unless a permittee can meet all of the criteria listed in 40 CFR 122.41(m)(4)(i)(A), (B), & (C). Any bypasses from this facility are subject to the reporting required in 40 CFR 122.41(l)(6) and per Missouri's Standard Conditions I, Section B, part 2.b. Additionally, Anticipated Bypasses include bypasses from peak flow basins or similar devices designed for peak wet weather flows.

☐ - Bypasses occur or have occurred at this facility.

☒ - This facility does not anticipate bypassing.

**303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):**

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

- ☐ - This facility discharges to a 303(d) listed stream.
- ☐ - This facility does not discharge to a 303(d) listed stream.
- ☒ - This facility discharges to a stream with an EPA approved TMDL.

**Part VI –2013 Water Quality Criteria for Ammonia**

On August 22, 2013, the U.S. Environmental Protection Agency (EPA) finalized new water quality criteria for ammonia, based on toxicity studies of mussels and gill breathing snails. Missouri is home to 69 of North America's mussel species, which are spread across the state. According to the Missouri Department of Conservation nearly two-thirds of the mussel species in Missouri are considered to be "of conservation concern". Nine species are listed as federally endangered, with an additional species currently proposed as endangered and another species proposed as threatened.

The adult forms of mussels that are seen in rivers, lakes, and streams are sensitive to pollutants because they are sedentary filter feeders. They vacuum up many pollutants with the food they bring in and cannot escape to new habitats, so they can accumulate toxins in their bodies and die. But very young mussels, called glochidia, are exceptionally sensitive to ammonia in water. As a result of a citizen suit, the EPA was compelled to conduct toxicity testing and develop ammonia water quality criteria that would be protective if young mussels may be present in a waterbody. The 2<sup>nd</sup> interim Ammonia limits are based upon this new criteria for ammonia.

## Part VII – Effluent Limits Determination

### APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:

As per Missouri's Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall's Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

- |   |   |
|---|---|
| <input type="checkbox"/> Missouri or Mississippi River [10 CSR 20-7.015(2)] | <input type="checkbox"/> Subsurface Water [10 CSR 20-7.015(7)]            |
| <input type="checkbox"/> Lake or Reservoir [10 CSR 20-7.015(3)]             | <input checked="" type="checkbox"/> All Other Waters [10 CSR 20-7.015(8)] |
| <input type="checkbox"/> Losing [10 CSR 20-7.015(4)]                        | <input type="checkbox"/> Metropolitan No-Discharge [10 CSR 20-7.015(5)]   |

### OUTFALL #001 – MAIN FACILITY OUTFALL

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

### EFFLUENT LIMITATIONS TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Modified	Previous Permit Limitations
Flow	MGD	1	*		*	No	*/*
BOD <sub>5</sub> (Interim)	mg/L	1		60	30	No	60/30
BOD <sub>5</sub> (Interim)	mg/L	7		15	10	Yes	60/30
BOD <sub>5</sub> (Final)	mg/L	8		*	*	Yes	15/10
CBOD <sub>5</sub>	mg/L	8		7.56	5.04	Yes	***
NBOD <sub>5</sub>	mg/L	8		2.19	1.46	Yes	***
TSS (Interim)	mg/L	1		60	30	No	60/30
TSS (Final)	mg/L	8		15	10	Yes	60/30
Ammonia as N (Apr 1 – Sep 30) (Interim)	mg/L	1, 3	3.7		1.9	No	3.7/1.9
Ammonia as N (Oct 1 – Mar 31) (Interim)	mg/L	1, 3	7.5		3.7	No	7.5/3.7
Ammonia as N (Apr 1 – Sep 30) (Interim)	mg/L	7	1.7		0.6	Yes	3.7/1.9
Ammonia as N (Oct 1 – Mar 31) (Interim)	mg/L	7	5.6		2.1	Yes	7.5/3.7
Ammonia as N (Final)	mg/L	8	1.0		0.3	Yes	2.4/0.6 6.9/2.1
Escherichia coli **	#/100mL	1, 3	1030		206	Yes	***
PARAMETER	Unit	Basis for Limits	Minimum		Maximum	Modified	Previous Permit Limitations
pH	SU	1	6.5			Yes	≥ 6.0
PARAMETER	Unit	Basis for Limits	Daily Minimum		Monthly Avg. Min	Modified	Previous Permit Limitations
Dissolved Oxygen (Interim)	mg/L	7	*		*	Yes	***
Dissolved Oxygen (Final)	mg/L	8	8		8	Yes	*/*
PARAMETER	Unit	Basis for Limits	Monthly Average		Quarterly Average	Modified	Previous Permit Limitations
Total Nitrogen (Interim)	mg/L	1	*		*	Yes	***
Total Nitrogen (Final)	mg/L	8	*		0.289	Yes	*/*
Total Phosphorus (Interim)	mg/L	1	*		*	Yes	***
Total Phosphorus (Final)	mg/L	8	*		0.007	Yes	*/*

\* - Monitoring requirement only.

\*\* - The Monthly Average for *E. coli* is a geometric mean.

\*\*\* - Parameter not previously established in previous state operating permit.

#### Basis for Limitations Codes:

- |  |                           |                                   |
|--|---------------------------|-----------------------------------|
| 1. State or Federal Regulation/Law       | 4. Antidegradation Review | 7. Best Professional Judgment     |
| 2. Water Quality Standard (includes RPA) | 5. Antidegradation Policy | 8. TMDL or Permit in lieu of TMDL |
| 3. Water Quality Based Effluent Limits   | 6. Water Quality Model    | 9. WET Test Policy                |



# OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- **Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may require the submittal of an operating permit modification.

**Carbonaceous Biological Oxygen Demand<sub>5</sub>, Nitrogenous Biological Oxygen Demand<sub>5</sub>, Total Nitrogen, Total Phosphorus, Ammonia, and Total Suspended Solids (TSS).** A Total Maximum Daily Load (TMDL) for Big Bottom Creek was approved in October 2010. This TMDL provided concentration wasteload allocations (WLAs) for CBOD<sub>5</sub>, NBOD<sub>5</sub>, Total Nitrogen, Total Phosphorus, Ammonia, and TSS nitrogen. Concentration-based limits have been calculated from the TMDL WLAs and compared to applicable technology (TBEL) and water quality (WQBEL) based effluent limits for these parameters (see chart below). The limits included in the permit are those that are most protective. Mass loading parameters were not included in the permit as the mass and concentration limits are both protective of the DO criteria and are duplicative. In addition, the modeling was run utilizing the design flow of the facility, 0.1183 MGD. A review of the DMRs show a majority of the actual flows reported on the Discharge Monitoring Reports were below the design flow. Since the actual flow is less, the concentration based limits will be more protective than the mass based limits.

Effluent Parameter	TMDL (mg/L)			TBEL / WQBEL (mg/L)	
	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	WEEKLY AVERAGE	MONTHLY AVERAGE
CBOD <sub>5</sub>	No Limit	7.56	5.04	NA (BOD 60)	NA (BOD 30)
NBOD <sub>5</sub>	No Limit	2.19	1.46	NA	NA
NH <sub>3</sub>	1.0	No Limit	0.3	No Limit	1.3
TSS	No Limit	15.0	10.0	60	30
Effluent Parameter	DAILY MAXIMUM	MONTHLY AVERAGE	QUARTERLY AVERAGE	WEEKLY AVERAGE	MONTHLY AVERAGE
TN	No Limit	*	0.289	NA	NA
TP	No Limit	*	0.007	NA	NA

\* Monitoring requirement only

## • **Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>).**

Per the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance, for conventional pollutants, and the Department's 2009 Dissolved Oxygen Modeling and Biochemical Oxygen Demand Effluent Limit Development Administrative Guidance document, the WLA is used as the Average Monthly Limit (AML). The Average Weekly Limit is calculated by multiplying the AML by 1.5.

$$WLA = AML = 5.04 \text{ mg/L}$$

$$AML = 5.04 \text{ mg/L}$$

$$AWL = AML * 1.5 = 5.04 * 1.5 = 7.56 \text{ mg/L}$$

$$AWL = 7.56 \text{ mg/L}$$

## • **Biochemical Oxygen Demand (BOD<sub>5</sub>).** (Interim)

Per the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance, for conventional pollutants, and the Department's 2009 Dissolved Oxygen Modeling and Biochemical Oxygen Demand Effluent Limit Development Administrative Guidance document, the WLA is used as the Average Monthly Limit (AML). The Average Weekly Limit is calculated by multiplying the AML by 1.5. Per 10 CSR 20-7.015(8)(A)5., CBOD = BOD – 5 mg/L.

$$CBOD \text{ WLA} = AML = 5.04 \text{ mg/L}$$

$$CBOD \text{ AML} = 5.04 \text{ mg/L}$$

$$BOD \text{ AML} = CBOD \text{ AML} + 5 \text{ mg/L} = 10 \text{ mg/L}$$

$$BOD \text{ AWL} = BOD \text{ AML} * 1.5 = 10 * 1.5 = 15 \text{ mg/L}$$

$$BOD \text{ AWL} = 15 \text{ mg/L}$$

- **Biochemical Oxygen Demand (BOD<sub>5</sub>).** (Final)

☒ - Monitoring only. This will allow the facility to calculate both mass-based and concentration-based NBOD<sub>5</sub>.  $\text{NBOD}_5 = \text{BOD}_5 - \text{CBOD}_5$

- **Nitrogenous Biochemical Oxygen Demand (NBOD<sub>5</sub>).**

Nitrogenous Biochemical Oxygen Demand is the difference between BOD<sub>5</sub> and CBOD<sub>5</sub>.  $\text{NBOD}_5 = \text{BOD}_5 - \text{CBOD}_5$

Per the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance, for conventional pollutants, and the Department's 2009 Dissolved Oxygen Modeling and Biochemical Oxygen Demand Effluent Limit Development Administrative Guidance document, the WLA is used as the Average Monthly Limit (AML). The Average Weekly Limit (AWL) is calculated by multiplying the AML by 1.5.

$$\text{WLA} = \text{AML} = 1.46 \text{ mg/L}$$

$$\text{AML} = 1.46 \text{ mg/L}$$

$$\text{AWL} = \text{AML} * 1.5 = 1.46 * 1.5 = 2.19 \text{ mg/L}$$

- **Total Suspended Solids (TSS).**

Per the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance, for conventional pollutants, the average weekly limit is calculated by multiplying the AML by 1.5.

$$\text{WLA} = \text{AML} = 10 \text{ mg/L}$$

$$\text{AML} = 10 \text{ mg/L}$$

$$\text{AWL} = \text{AML} * 1.5 = 10 * 1.5 = 15 \text{ mg/L}$$

- **Total Nitrogen (Interim).** Monitoring required for facilities greater than 100,000 gpd design flow per 10 CSR 20-7.015(9)(D)7. Total Nitrogen shall be determined by testing for Total Kjeldahl Nitrogen (TKN) and Nitrate + Nitrite and reporting the sum of the results (reported as N). Nitrate + Nitrite can be analyzed together or separately.
- **Total Nitrogen (Final).** The NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both average monthly limits and maximum daily limits for all dischargers other than publicly owned treatment works (POTWs), and as average weekly limits and average monthly limits for POTWs.

In the March 3, 2004 EPA Memorandum with the subject of; Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System, the Office of Wastewater Management cautioned that the steady-state statistical procedures described in EPA's Technical Support Document for Water Quality-based Toxics Control (TSD) were not applicable or appropriate for developing nutrient limits for the main stem of Chesapeake Bay and its tidal tributaries. The memo stated that developing permit limits for nutrients affecting Chesapeake Bay and its tidal tributaries is different from setting limits for toxic pollutants because the exposure period of concern for nutrients is longer than one month, and can be up to a few years, and the average exposure rather than the maximum exposure is of concern. The statistical derivation procedure described in the TSD for acute and chronic aquatic life protection is not applicable to exposure periods more than 30 days (see TSD page 105). The Office of Wastewater Management concluded that due to the characteristics of nutrient loading and its effects on the water quality in Chesapeake Bay and its tidal tributaries and because the derivation of appropriate daily, weekly or monthly limits is not possible for the reasons described above, that it is therefore "impracticable" to express permit effluent limitations as daily maximum, weekly average, or monthly average effluent limitations. Therefore the Department has determined that the WLA provided in the TMDL will be applied as a Quarterly Average Limit (QAL), as an average monthly limit is not practicable due to the long term effects of nutrients on streams.

$$\text{WLA} = \text{QAL} = 0.289 \text{ mg/L}$$

$$\text{QAL} = 0.289 \text{ mg/L}$$

In addition to the Quarterly Average Limit, the facility will be required to monitor Total Nitrogen monthly as a monitoring only requirement.

- **Total Phosphorus (Interim).** Monitoring required for facilities greater than 100,000 gpd design flow per 10 CSR 20-7.015(9)(D)7
- **Total Phosphorus (Final).** The NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both average monthly limits and maximum daily limits for all dischargers other than publicly owned treatment works (POTWs), and as average weekly limits and average monthly limits for POTWs.

In the March 3, 2004 EPA Memorandum with the subject of; Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System, the Office of Wastewater Management cautioned that the steady-state statistical procedures described in EPA's Technical Support Document for Water Quality-based Toxics Control (TSD) were not applicable or appropriate for developing nutrient limits for the main stem of Chesapeake Bay and its tidal tributaries. The memo stated that developing permit limits for nutrients affecting Chesapeake Bay and its tidal tributaries is different from setting limits for toxic pollutants because the exposure period of concern for nutrients is longer than one month, and can be up to a few years, and the average exposure rather than the maximum exposure is of concern. The statistical derivation procedure described in the TSD for acute and chronic aquatic life protection is not applicable to exposure periods more than 30 days (see TSD page 105). The Office of Wastewater Management concluded that due to the characteristics of nutrient loading and its effects on the water quality in Chesapeake Bay and its tidal tributaries and because the derivation of appropriate daily, weekly or monthly limits is not possible for the reasons described above, that it is therefore "impracticable" to express permit effluent limitations as daily maximum, weekly average, or monthly average effluent limitations. Therefore the Department has determined that the WLA provided in the TMDL will be applied as a Quarterly Average Limit (QAL), as an average monthly limit is not practicable due to the long term effects of nutrients on streams.

$$WLA = QAL = 0.007 \text{ mg/L}$$

$$QAL = 0.007 \text{ mg/L}$$

In addition to the Average Annual Limit, the facility will be required to monitor Total Phosphorus monthly as a monitoring only requirement.

- **Total Ammonia Nitrogen (Interim).** The 2<sup>nd</sup> interim Ammonia limits are based upon the EPA's 2013 finalized new water quality criteria for ammonia, based on toxicity studies of mussels and gill breathing snails. Background total ammonia nitrogen = 0.01 mg/L. No mixing considerations allowed; therefore, WLA = appropriate criterion.

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
Summer	26	7.8	0.7	3.4
Winter	6	7.8	2.3	13

**Summer: April 1 – September 30**

Chronic WLA:  $C_e = ((0.2 + 0.0)0.7 - (0.0 * 0.01))/0.2$   
 $C_e = 0.7 \text{ mg/L}$

Acute WLA:  $C_e = ((0.2 + 0.0)3.4 - (0.0 * 0.01))/0.2$   
 $C_e = 3.4 \text{ mg/L}$

$$LTA_c = 0.7 \text{ mg/L } (0.780) = 0.55 \text{ mg/L}$$

[CV = 0.6, 99<sup>th</sup> Percentile, 30 day avg.]

$$LTA_a = 3.4 \text{ mg/L } (0.321) = 1.09 \text{ mg/L}$$

[CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 0.55 \text{ mg/L } (3.11) = 1.7 \text{ mg/L}$$

[CV = 0.6, 99<sup>th</sup> Percentile]

$$AML = 0.55 \text{ mg/L } (1.19) = 0.6 \text{ mg/L}$$

[CV = 0.6, 95<sup>th</sup> Percentile, n = 30]

**Winter: October 1 – March 31**

Chronic WLA:  $C_e = ((0.2 + 0.0)2.3 - (0.0 * 0.01))/0.2$   
 $C_e = 2.3 \text{ mg/L}$

Acute WLA:  $C_e = ((0.2 + 0.0)13 - (0.0 * 0.01))/0.2$   
 $C_e = 13 \text{ mg/L}$

$$LTA_c = 2.3 \text{ mg/L } (0.780) = 1.79 \text{ mg/L}$$

[CV = 0.6, 99<sup>th</sup> Percentile, 30 day avg.]

$$LTA_a = 13 \text{ mg/L } (0.321) = 4.14 \text{ mg/L}$$

[CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 1.79 \text{ mg/L } (3.11) = 5.6 \text{ mg/L}$$

[CV = 0.6, 99<sup>th</sup> Percentile]

$$AML = 1.79 \text{ mg/L } (1.19) = 2.1 \text{ mg/L}$$

[CV = 0.6, 95<sup>th</sup> Percentile, n = 30]

- **Total Ammonia Nitrogen (Final).**  $WLA_c = 0.3 \text{ mg/L}$  per the 2010 EPA approved TMDL. The TMDL discusses that seasonal variation is addressed by the TMDL identifying a Loading Capacity that is protective of the Dissolved Oxygen target during the 7Q10 low flow period. Therefore the  $WLA_c$  will be used for the limit calculation. As the Ammonia limit is set to be protective of the Dissolved Oxygen target, seasonal limits are not applicable. The  $WLA_c$  for the TMDL is more protective than the  $WLA_a$  and  $WLA_c$  for protection of aquatic life, therefore the TMDL limits will apply. Effluent Limits were determined using the US EPA's Technical Support Document For Water Quality-based Toxics Control (EPA/505/2-90-001) Permit Limit Derivation from Single, Steady-State Model Output. The single WLA as provided in the TMDL was considered the chronic WLA.

Chronic WLA:  $C_e = 0.3 \text{ mg/L}$

$LTA_c = 0.3 \text{ mg/L} (0.67) = 0.2 \text{ mg/L}$

[CV = 0.97, 99<sup>th</sup> Percentile, 30 day avg.]

$MDL = 0.2 \text{ mg/L} (4.79) = 1.0 \text{ mg/L}$

[CV = 0.97, 99<sup>th</sup> Percentile]

$AML = 0.2 \text{ mg/L} (1.32) = 0.3 \text{ mg/L}$

[CV = 0.97, 95<sup>th</sup> Percentile, n=30]

- ***Escherichia coli (E. coli)*.** Monthly average of 206 per 100 mL as a geometric mean and Daily Maximum of 1030 per 100 mL during the recreational season (April 1 – October 31), to protect Whole Body Contact Recreation (B) designated use of the receiving stream, as per 10 CSR 20-7.031(5)(C). An effluent limit for both monthly average and daily maximum is required by 40 CFR 122.45(d). The Geometric Mean is calculated by multiplying all of the data points and then taking the nth root of this product, where n = # of samples collected. For example: Five *E. coli* samples were collected with results of 1, 4, 6, 10, and 5 (#/100mL). Geometric Mean = 5<sup>th</sup> root of  $(1)(4)(6)(10)(5) = 5^{\text{th}} \text{ root of } 1,200 = 4.1 \text{ \#/100mL}$ .
- **pH.**  $\geq 6.5 \text{ SU}$ . Technology based effluent limitations of 6.0-9.0 SU [10 CSR 20-7.015] are not protective of the Water Quality Standard, which states that water contaminants shall not cause pH to be outside the range of 6.5-9.0 SU. 10 CSR 20-7.015 allows pH for lagoons to be maintained above 6.0 SU. With no mixing zone, the water quality standard,  $\geq 6.5 \text{ SU}$ , must be met at the outfall.
- **Dissolved Oxygen.** The 2010 EPA approved TMDL requires a minimum Dissolved Oxygen limit of 8.0 mg/L.
- **Parameters Removed.** Temperature was removed as it did not show a reasonable potential to violate Water Quality Standards.

#### Minimum Sampling and Reporting Frequency Requirements.

PARAMETER	SAMPLING FREQUENCY	REPORTING FREQUENCY
Flow	twice/week	once/month
BOD <sub>5</sub>	once/month	once/month
CBOD <sub>5</sub>	once/month	once/month
NBOD <sub>5</sub>	once/month	once/month
TSS	once/month	once/month
Ammonia as N	once/month	once/month
pH	once/month	once/month
Total Nitrogen (Interim)	once/quarter	once/quarter
Total Phosphorus (Interim)	once/quarter	once/quarter
Total Nitrogen (Final)	once/month	once/quarter
Total Phosphorus (Final)	once/month	once/quarter
<i>E. coli</i>	once/month	once/month
pH	once/month	once/month
Dissolved Oxygen	once/month	once/month

#### Sampling Frequency Justification:

Sampling and Reporting Frequency was retained from previous permit, except for flow, which was increased to twice per week. This increase was to capture additional flow data as this facility has previously been reported as having hydraulic overloading. Weekly sampling is required for *E. coli*, per 10 CSR 20-7.015(9)(D)6.A. The interim Total Nitrogen and Total Phosphorus are to be collected quarterly per 10 CSR 20-7.015(9)(D)7.

#### Sampling Type Justification

As per 10 CSR 20-7.015, BOD<sub>5</sub>, including CBOD<sub>5</sub> and NBOD<sub>5</sub> and TSS collected for lagoons may be grab samples. Grab samples must be collected for pH, Ammonia as N, *E. coli*, Dissolved Oxygen and Total Phosphorus. This is due to the holding time restriction for *E. coli*, the volatility of Ammonia, and the fact that pH and DO cannot be preserved and must be sampled in the field. As Ammonia and Total Phosphorus samples must be immediately preserved with acid, these samples are to be collected as a grab. For further information on sampling and testing methods please review 10 CSR 20-7.015(9)(D) 2.

**PERMITTED FEATURE #SM1 & #SM2 – INSTREAM MONITORING (UPSTREAM AND DOWNSTREAM)**

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

**MONITORING REQUIREMENTS TABLE:**

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Modified	Previous Permit Limitations
Temperature	° C	8	*		*	No	*/
Ammonia as N	mg/L	8	*		*	No	*/
PARAMETER	Unit	Basis for Limits	Minimum		Maximum	Modified	Previous Permit Limitations
pH	SU	8	*		*	No	*/
PARAMETER	Unit	Basis for Limits	Daily Minimum		Monthly Avg. Min	Modified	Previous Permit Limitations
Dissolved Oxygen (DO)	mg/L	8	*		*	No	*/

\* - Monitoring requirement only.

**Basis for Limitations Codes:**

- |  |                                   |
|--|-----------------------------------|
| 1. State or Federal Regulation/Law       | 6. Water Quality Model            |
| 2. Water Quality Standard (includes RPA) | 7. Best Professional Judgment     |
| 3. Water Quality Based Effluent Limits   | 8. TMDL or Permit in lieu of TMDL |
| 4. Antidegradation Review                | 9. WET Test Policy                |
| 5. Antidegradation Policy                |                                   |

**PERMITTED FEATURE #SM1 & #SM2 – DERIVATION AND DISCUSSION OF MONITORING REQUIREMENTS:**

- **Temperature.** Monitoring requirement only. This parameter is required to be collected instream by the 2010 EPA approved TMDL.
- **Ammonia as N.** Monitoring requirement only. This parameter is required to be collected instream by the 2010 EPA approved TMDL.
- **pH.** Monitoring requirement only. This parameter is required to be collected instream by the 2010 EPA approved TMDL.
- **Dissolved Oxygen.** Monitoring requirement only. This parameter is required to be collected instream by the 2010 EPA approved TMDL.

**Minimum Sampling and Reporting Frequency Requirements.**

PARAMETER	SAMPLING FREQUENCY	REPORTING FREQUENCY
Temperature	once/month	once/month
Ammonia as N	once/month	once/month
pH	once/month	once/month
Dissolved Oxygen	once/month	once/month

**Sampling Frequency Justification:**

The sampling and reporting frequency for instream monitoring has been established to match the sampling frequency of the effluent parameters.

**Sampling Type Justification**

As Ammonia as N samples must be immediately preserved; these samples are to be collected as a grab. Temperature, pH, and Dissolved Oxygen must be collected as grab as these parameters cannot be preserved and must be sampled in the field.

## **Part VIII – Cost Analysis for Compliance**

Pursuant to Section 644.145, RSMo., the Department is required to determine whether a permit or decision is affordable and makes a “finding of affordability” for certain permitting and enforcement decisions. This requirement applies to discharges from combined or separate sanitary sewer systems or publically-owned treatment works.

- The Department is not required to complete a cost analysis for compliance because the facility is not a combined or separate sanitary sewer system for a publically-owned treatment works.

## **Part IX – Administrative Requirements**

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

### **PERMIT SYNCHRONIZATION:**

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together will all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the Department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than 4 years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit. This permit will be synchronized at the next permit renewal.

### **PUBLIC NOTICE:**

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

☒ - The Public Notice period for this operating permit was from September 25, 2015 to October 26, 2015. Responses to the Public Notice of this operating permit did not warrant the modification of effluent limits and/or the terms and conditions of this permit. Mass loading parameters were removed from the permit.

**DATE OF FACT SHEET: DECEMBER 16, 2015**

### **COMPLETED BY:**

**BRANT FARRIS, ENVIRONMENTAL SPECIALIST III**  
**MISSOURI DEPARTMENT OF NATURAL RESOURCES**  
**WATER PROTECTION PROGRAM**  
**OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT**  
**(660) 385-8061**  
**brant.farris@dnr.mo.gov**

APPENDIX – TMDL TABLE 14:

**Table 14. WLAs for Lake Forest Estates Subdivision WWTP (MO0035742) in the Big Bottom Creek Watershed**

Effluent Parameter	Design Flow (MGD)	Existing Permit Limit (mg/L)		WLA at Design Flow based on QUAL2K and LDC modeling (mg/L)		Percent Reduction
		Concentration (mg/L)	Load (lbs/day)	Concentration (mg/L)	Load (lbs/day)	
CBOD <sub>5</sub>	0.1183	No limit	No limit	5.04	4.99	Not applicable
NBOD <sub>5</sub>	0.1183	No limit	No limit	1.46	1.45	Not applicable
TN	0.1183	No limit	No limit	0.289	0.29	Not applicable
TP	0.1183	No limit	No limit	0.007	0.01	Not applicable
NH <sub>3</sub>	0.1183	Daily Maximum = 3.7 <sup>12</sup> - 7.5 <sup>13</sup> Monthly Average = 1.9 <sup>14</sup> - 3.7 <sup>15</sup>	3.7 - 7.4 1.9 - 3.7	0.3	0.9	50
TSS	0.1183	Weekly Average = 60 Monthly Average = 30	= 59.2 = 29.6	10.0	9.9	67

Notes: CBOD<sub>5</sub> is calculated using simulated BOD<sub>5</sub> divided by 1.29, based on 1998 EPA modeling guidance for NH<sub>3</sub> toxicity and DO modeling. NBOD<sub>5</sub> is the difference between BOD<sub>5</sub> and CBOD<sub>5</sub>. TN target loading for point sources was based on 289 µgN/L, Ecoregion 39 TN value. TP target loading for point sources was based on 7 µgP/L, Ecoregion 39 TP value. Existing permit limit loads (lbs/day) are based on existing design flow and monthly average limits.

**Water Protection Program, Financial Assistance Center  
Clean Water State Revolving Fund Grant Eligibility Evaluation Form**

Applicant:	<u>Lake Forest Clean Water District</u>	Project No.:	<u></u>
	<u></u>	Missouri State Operating	<u></u>
Facility:	<u>Lake Forest Estates</u>	Permit No.:	<u>MO-0035742</u>
Date Reviewed:	<u></u>	County:	<u>Ste. Genevieve</u>
Total Project Amount:	<u>\$5,736,500</u>	Potential Grant:	<u></u>

The amount of additional subsidization (ie grant) funds available to Missouri Clean Water State Revolving Fund projects each year is determined by a formula in federal statute. Pursuant to the Federal Water Pollution Control Act section 603(i), the Missouri Department of Natural Resources' developed this evaluation form to determine Clean Water State Revolving Fund grant eligibility based on affordability. As available grants are limited, this evaluation provides the Department with a means to identify eligible grant recipients and obligate grant funds to applicants with the greatest need each year through a spending plan, referred to as the Clean Water State Revolving Fund Intended Use Plan.

This evaluation indicates the project IS/IS NOT grant eligible. This evaluation provides a grant eligibility score that will assist the Department to prioritize funding among eligible applicants in **[Fiscal Year xxxx] Clean Water State Revolving Fund Intended Use Plan**. However, this evaluation represents an eligibility determination and is not a binding commitment or an actual award of financial assistance. Applicants have 2 years from the date of the Intended Use Plan to utilize the funds. In the event the loan and grant are not awarded within this timeframe, the applicant will need to re-compete for both the loan and grant funds by re-applying.

<b>POPULATION</b>			
<b>Total population served by project</b>			50
Population of municipality or service area =	773	Ineligible, Pop. > 10,000	
Population 3,300 or less			
Population of 3,301 to 7,500			
Population of 7,501 to 10,000			
<b>UNEMPLOYMENT RATE</b>			
<b>Comparison of municipality or service area unemployment with State Average</b>			0
Recipient Unemployment Rate =	3.0%	State Unemployment Rate = 5.8%	
Unemployment Rate > 1% above State Average			
Unemployment Rate ± 1% State Average			
Unemployment Rate > 1% below State Average			
<b>INCOME</b>			
<b>Comparison of municipality or service area Median Household Income (MHI) with State average</b>			30
Recipient MHI =	\$44,509	State MHI = \$52,801	
75% of State MHI = \$39,600.75			
MHI < 75% of State MHI			
MHI 75% to 100% of State MHI			
MHI > State MHI			
<b>Proposed User Rates in municipality or service area as percentage of MHI</b>			75
Recipient User Rate =	\$111.16	Recipient MHI = \$44,509	
User Rates ≥ 2% MHI			
User Rates 1.5 to < 2%			
User Rates 1 to <1.5% (user rate X 12 months) / Recipient MHI X 100 = 3.0%			
User Rates < 1% MHI			
<b>OTHER RELEVANT SOCIOECONOMIC DATA</b>			
<b>Percentage of Households Below Poverty Level</b>			30
Households Below Poverty Level =	19.0%	State Average = 14.6%	
Households Below Poverty Level >10% above State Average			
Households Below Poverty Level ± 10% State Average			
Households Below Poverty Level >10% below State Average			
<b>POPULATION TREND</b>			
<b>Population during the last 5 years (including the last decennial census)</b>			20
Population decline or stagnant			
Population growth			
195 Points required for SRF Grant Eligibility = YES			205